

SAUSALITO-MARIN CITY SANITARY DISTRICT

HIGHWAY BOOSTER PUMP STATION IMPROVEMENT PROJECT

Addendum No. 2

The following shall modify the Contract Documents. The work shall be accomplished in accordance with such modifications. It is required that this addendum be attached to the Specifications. This addendum contains 1 page, with no attachments.

IMPORTANT: Receipt of this Addendum must be acknowledged in the space provided on the Bid Form when your bid is submitted. Failure to acknowledge receipt of this addendum may constitute grounds for rejection of the bid.

Addendum Items:

1.1: Drawing S02, Section B: Correct the fence height dimension to be 5'-0" where it is located above the 3' retaining wall so that it matches the height of adjacent fencing.

1.2: Fence Clarification:

a) Drawing S02, Key Note 9 references Caltrans Standard Details for fencing. A rail shall be used at the top of the fence in lieu of a standard tension wire.

b) Section 02820, Paragraph 2.02.A.2.a: Delete item 2 specifying tension wire. A rail shall be used at the top of the fence in lieu of a tension wire.

This Addendum No. 2 shall become part of the Contract and all provisions of the Contract shall apply thereto.