



	INFLUENT FLOW	FFR RECYCLE	HIGH TIDE LEVEL
MAX PWWF	13.0 MGD	-6.5 MGD	105.5 FT
MAX FFR	6.0 MGD	0.0 MGD	103.0 FT
ADWF	1.3 MGD	2.6 MGD	103.0 FT

TREATMENT PLANT
HORIZONTAL NTS, VERTICAL 1"=5'

FILENAME: 055-003-Hydraulic Profile 10-12-11 12:41pm mtakemoto XREFS: X-SMCSO-TBLK K<<--

0' 1"
— VERIFY SCALES —
BAR IS ONE INCH
LONG ON FULL
SIZE DRAWING,
IF NOT ONE INCH
LONG ON THIS
DRAWING, ADJUST
SCALES ACCORDINGLY



REV	DATE	BY	APVD	DESCRIPTION
▲				
▲				
▲				
▲				

DESIGNED	M. TAKEMOTO	SUBMITTED:	
DRAWN	SJUNG		RMC PROJ ENGR
CHECKED		APPROVED:	
			RMC ENGR

SAUSALITO - MARIN CITY SANITARY DISTRICT

HYDRAULIC PROFILE
WITH NEW HEADWORKS/PRIMARY

DWG NO G-5

SHEET NO OF

PROJ NO 055-003

DATE OCTOBER 2011