



**MILLER PACIFIC
ENGINEERING GROUP**

**UPDATED GEOTECHNICAL INVESTIGATION
SAUSALITO MARIN CITY SANITARY DISTRICT
COLOMA PUMP STATION
SAUSALITO, CALIFORNIA**

July 5, 2019

Job No. 2213.004

Prepared For:
Carollo Engineers, Inc.
Attn: James Wickstrom
2700 Ygnacio Valley Road, Suite 300
Walnut Creek, California 94598

CERTIFICATION

This document is an instrument of service, prepared by or under the direction of the undersigned professionals, in accordance with the current ordinary standard of care. The service specifically excludes the investigation of polychlorinated byphenols, radon, asbestos or any other hazardous materials. The document is for the sole use of the client and consultants on this project. No other use is authorized. If the project changes, or more than two years have passed since issuance of this report, the findings and recommendations must be updated.

MILLER PACIFIC ENGINEERING GROUP
(a California corporation)

REVIEWED BY:



Rusty Arend
Geotechnical Engineer No. 3031
(Expires 6/30/21)



Eric Dabanian
Geotechnical Engineer No. 2526
(Expires 6/30/21)

UPDATED GEOTECHNICAL INVESTIGATION
SAUSALITO MARIN CITY SANITARY DISTRICT
COLOMA PUMP STATION IMPROVEMENTS
SAUSALITO, CALIFORNIA

TABLE OF CONTENTS

| | | |
|------------|---|-----------|
| 1.0 | INTRODUCTION..... | 1 |
| 2.0 | PROJECT DESCRIPTION..... | 2 |
| 3.0 | SITE CONDITIONS..... | 2 |
| 3.1 | Regional Geology | 2 |
| 3.2 | Seismicity | 3 |
| 3.3 | Surface Conditions | 3 |
| 3.4 | Site History | 4 |
| 3.5 | Field Exploration and Geotechnical Laboratory Testing | 4 |
| 3.6 | Environmental Laboratory Testing..... | 4 |
| 3.7 | Subsurface Conditions and Groundwater..... | 5 |
| 4.0 | GEOLOGIC HAZARDS | 5 |
| 4.1 | Seismic Shaking | 5 |
| 4.2 | Liquefaction and Related Effects | 6 |
| 4.3 | Settlement | 7 |
| 4.4 | Corrosive Soils | 8 |
| 5.0 | CONCLUSIONS AND RECOMMENDATIONS | 9 |
| 5.1 | Seismic Design | 9 |
| 5.2 | Earthwork | 9 |
| 5.2.1 | Subgrade Preparation | 9 |
| 5.2.2 | Excavations | 10 |
| 5.2.3 | Excavation Bottom Stabilization | 11 |
| 5.2.4 | Fill Materials | 11 |
| 5.2.5 | Fill Placement and Compaction..... | 11 |
| 5.3 | Foundation and Pump Station Structural Design | 11 |
| 5.4 | Temporary Support of Excavations | 13 |
| 5.5 | Instrumentation and Monitoring | 14 |
| 5.6 | New Pavements | 14 |
| 6.0 | SUPPLEMENTAL GEOTECHNICAL SERVICES | 15 |
| 7.0 | LIMITATIONS | 15 |
| 8.0 | LIST OF REFERENCES..... | 14 |

FIGURE 1: SITE LOCATION MAP
FIGURE 2: SITE PLAN
FIGURE 3: REGIONAL GEOLOGIC MAP
FIGURE 4: ACTIVE FAULT MAP
FIGURE 5: LIQUEFACTION SUSCEPTIBILITY MAP
FIGURE 6: LIQUEFACTION ANALYSES
FIGURE 7: TUNNELMAN'S GROUND CLASSIFICATION FOR SOILS
FIGURE 8: PUMP STATION DESIGN CRITERIA

TABLE 1: ESTIMATED PEAK GROUND ACCELERATIONS FOR PRINCIPAL ACTIVE FAULTS
TABLE 2: PRELIMINARY STRUCTURAL LOADS
TABLE 3: 2016 CALIFORNIA BUILDING CODE SEISMIC DESIGN CRITERIA
TABLE 4: SOIL PARAMETERS FOR LATERAL PILE ANALYSIS
TABLE 5: DAMAGE THRESHOLDS DUE TO CONTINUOUS VIBRATION
TABLE 6: PRELIMINARY ASPHALT-CONCRETE PAVEMENT SECTIONS

APPENDIX A: SUBSURFACE EXPLORATION AND LABORATORY TESTING
APPENDIX B: ENVIRONMENTAL LABORATORY TEST RESULTS
APPENDIX C: RESULTS OF LATERAL PILE ANALYSIS

UPDATED GEOTECHNICAL INVESTIGATION
SAUSALITO MARIN CITY SANITARY DISTRICT
COLOMA PUMP STATION IMPROVEMENTS
SAUSALITO, CALIFORNIA

1.0 INTRODUCTION

This report presents the results of our updated Geotechnical Investigation for the Sausalito Marin City Sanitary District's (SMCSD) Coloma Pump Station Project in Sausalito, California. The project site is located just south of the intersection of Coloma Street and Bridgeway, as shown on the Site Location Map, Figure 1.

Our work was performed in accordance with our Agreement for Professional Services dated April 11, 2017. The purpose of our Geotechnical Investigation was to explore subsurface conditions and to develop geotechnical criteria for design and construction of the pump station improvements. The scope of our services includes:

- Review of readily available geotechnical and geologic reference materials, including the preliminary geotechnical evaluation prepared by DCM Consulting, Inc. (DCM, 2014).
- Exploration of subsurface conditions with two borings located within the general vicinity of the pump station.
- Geotechnical laboratory testing to estimate pertinent engineering properties of the soils encountered during our exploration.
- Environmental laboratory testing for volatile organic compounds, semi-volatile organic compounds, total petroleum hydrocarbons, CAM 17 metals and corrosivity.
- Evaluation of relevant geologic hazards including seismic shaking, settlement, liquefaction and other hazards.
- Preparing geotechnical recommendations and design criteria related to foundations, lateral pressures, temporary support of excavations, earthwork, trench backfill, new pavement sections, seismic design, and other geotechnical-related items.
- Preparation of this report which summarizes our subsurface exploration and laboratory testing programs, evaluation of relevant geologic hazards, and geotechnical recommendations and design criteria.

This report was completed under our Phase 2 services for the project. Subsequent phases of work may include geotechnical plan review and observation and testing of geotechnical-related work items during construction.

2.0 PROJECT DESCRIPTION

Based on our discussions with the project team and review of Preliminary Drawings (Carollo, 2019), we understand the planned improvements generally consist of constructing a new pump station within the City of Sausalito right-of-way just south of Coloma Street. The circular structure will be located largely within the footprint of the existing City of Sausalito's Whiskey Springs Pump Station and will occupy an approximately 16-foot-diameter footprint with an invert depth of about 26.5 feet below the existing ground surface. A new underground valve vault, electrical building and flow meter vault will be constructed south of the pump station with invert depths of about 7.5 feet, 13 feet and 7 feet below grade, respectively. The planned improvements also include constructing a new transformer and generator pad adjacent to the new pump station.

Other improvements are expected to include constructing new sewer pipelines and manholes which connect to the existing and proposed facilities. Temporary shoring will be required to facilitate construction of the new underground improvements. A new driveway will also be constructed along the western property boundary to provide access to the site from Coloma Street. The proposed improvements are shown on the Site Plan, Figure 2.

3.0 SITE CONDITIONS

3.1 Regional Geology

The project site lies within the Coast Ranges geomorphic province of California. Regional topography within the Coast Ranges province is characterized by northwest-southeast trending mountain ridges and intervening valleys that parallel the major geologic structures, including the San Andreas Fault System. The province is also generally characterized by abundant landsliding and erosion, owing in part to its typically high levels of precipitation and seismic activity.

The oldest rocks in the region are the sedimentary, igneous, and metamorphic rocks of the Jurassic-Cretaceous age (190- to 65-million years old) Franciscan Complex. Within Marin County, a variety of sedimentary and volcanic rocks of Tertiary (1.8- to 65-million years old) and Quaternary (less than 1.8-million years old) age locally overlie the basement rocks of the Franciscan Complex. Tectonic deformation and erosion during late Tertiary and Quaternary time (the last several million years) formed the prominent coastal ridges and intervening valleys typical of the Coast Ranges province. The youngest geologic units in the region are Quaternary-age (last 1.8 million years) sedimentary deposits, including alluvial deposits which partially fill most of the valleys and colluvial deposits which typically blanket the lower portions of surrounding slopes.

The project site is located within lower-lying terrain near the western margins of the San Francisco Bay. Regional geologic mapping by the California Division of Mines and Geology (CDMG, 1976) indicates the site is underlain by artificial fill over Bay Mud and is located just north of a mapped boundary between Bay Mud and colluvial soils. Franciscan mélangé is mapped near the base of

the hillside located several hundred feet south of the site. A Regional Geologic Map and descriptions of the mapped geologic units are shown on Figure 3.

3.2 Seismicity

The project site is located within the seismically active San Francisco Bay Area and will therefore experience the effects of future earthquakes. Earthquakes are the product of the build-up and sudden release of strain along a “fault” or zone of weakness in the earth's crust. Stored energy may be released as soon as it is generated or it may be accumulated and stored for long periods of time. Individual releases may be so small that they are detected only by sensitive instruments, or they may be violent enough to cause destruction over vast areas.

Faults are seldom single cracks in the earth's crust but are typically comprised of localized shear zones which link together to form larger fault zones. Within the Bay Area, faults are concentrated along the San Andreas Fault zone. The movement between rock formations along either side of a fault may be horizontal, vertical, or a combination and is radiated outward in the form of energy waves. The amplitude and frequency of earthquake ground motions partially depends on the material through which it is moving. The earthquake force is transmitted through hard rock in short, rapid vibrations, while this energy becomes a long, high-amplitude motion when moving through soft ground materials, such as Bay Mud.

An “active” fault is one that shows displacement within the last 11,000 years (i.e., Holocene) and has a reported average slip rate greater than 0.1 mm per year. The California Division of Mines and Geology (1998) has mapped various active and inactive faults in the region. These faults, defined as either California Building Code Source Type “A” or “B,” are shown in relation to the project site on the attached Active Fault Map, Figure 4. The nearest known active faults to the site are the San Andreas and San Gregorio Faults located approximately 10.1 kilometers (6.3 miles) and 13.6 kilometers (8.5 miles) southwest of the site, respectively.

3.3 Surface Conditions

The project area is located within the City of Sausalito right-of-way along the western side of Bridgeway, just south of the Coloma Street intersection. The site is bordered to the east by Bridgeway, to the north by Coloma Street, to the south by public landscaped areas, and to the west by a private townhome development. The ground surface is covered with grass, trees and sidewalks and an asphalt-paved driveway which is oriented roughly north/south along the western property boundary. The site is gently sloping with surface elevations ranging from about 13 to 17 feet¹.

The existing Whiskey Springs Pump Station is located within the proposed Coloma Pump Station footprint and will be removed as part of the planned improvements. The concrete structure occupies an approximately 27-foot by 17-foot footprint and is embedded roughly 23 feet below grade with an

¹ Elevation references correspond to NAVD88.

invert elevation of about – 5 feet. A portable standby generator is located adjacent to the existing pump station within the asphalt-paved driveway. A storm drain junction box is located near the north end of the site and receives flow from two 18-inch corrugated metal pipe storm drains aligned within Coloma Street. The junction box discharges to a 53-inch by 83-inch elliptical concrete storm drain that extends northeast into the adjacent intersection. Various other underground utilities exist within and around the project area, as shown on Figure 2.

3.4 Site History

In addition to available geotechnical and geologic reference information, we reviewed several historic topographic maps to assess site development history and changes in surface topography. The maps were obtained from the United States Geological Survey website and were recorded between 1895 and 2015 at a variety of scales. The maps indicate the site is located within previous tidal marshlands which were filled prior to the 1950's as part of reclamation and development of the surrounding shoreline areas.

3.5 Field Exploration and Geotechnical Laboratory Testing

We explored subsurface conditions near the proposed force main alignment on July 12, 2017 with two borings at the approximate locations shown on Figure 2. The borings were excavated using track-mounted drilling equipment to approximate depths ranging from 16.5 to 26.5 feet below the ground surface. The borings were logged by our Field Geologist and samples were obtained for classification and laboratory testing. We prepared boring logs based on soil descriptions in the field, as well as visual examination and testing of the soil samples in our laboratory. The boring logs are presented in Appendix A.

Geotechnical laboratory testing of soil samples from the exploratory borings included determination of moisture content, dry density, unconfined compressive strength and the amount of material passing a No. 200 sieve. The results of our laboratory tests are presented on the boring logs and our laboratory testing program is discussed in greater detail in Appendix A.

3.6 Environmental Laboratory Testing

We composited soil samples collected at various depths from Borings 1 and 2 and delivered them to Analytical Sciences of Petaluma, California. The composite sample was tested for the presence of volatile organic compounds (VOC), semi-volatile organic compounds (SVOC), total petroleum hydrocarbons (TPH) and 17 metals identified by California Administrative Manual (CAM) as hazardous material when found to exceed a total threshold limit concentration (TTLC) or soluble threshold limit concentration (STLC) as specified by the California Code of Regulations (CCR), Title 22. The results of the environmental laboratory testing are presented in Appendix B.

While many of the CAM 17 metals were detected, the test results indicate the levels are below the TTLC. The results of our CAM 17 and TPH testing are presented in Appendix B. The results of our environmental testing indicate that onsite soils are generally not considered hazardous toxic waste in accordance with CAM regulations.

3.7 Subsurface Conditions and Groundwater

Based on our field exploration, subsurface conditions are generally consistent with geologic mapping, and consist of artificial fill over Bay Mud with fill thickness at the boring locations ranging from about 9 to 10 feet. The fill encountered in our borings is heterogeneous and contains variable amounts of clay, silt, sand, and gravel. While not directly observed, the fill may also contain cobbles, boulders, wood, organic material, and other debris which could not be retrieved within the samples or detected by the relatively small diameter borings. The Bay Mud encountered in our borings generally consists of very soft to soft silty clay of high plasticity.

Groundwater was encountered in both borings at about 12 feet below ground surface. Because the borings were not left open for an extended period of time, a stabilized depth to groundwater may not have been observed. Groundwater elevations fluctuate seasonally and with changes in tidal elevations and higher groundwater levels may be present during periods of intense rainfall and/or high tide.

A cursory search of the State Water Resources Control Board's Geotracker website indicates that groundwater monitoring wells were installed as part of various environmental studies near the Shell Service Station located roughly 450 feet northwest of the project site (Cambria, 2003). The monitoring data from these studies indicates the groundwater elevation at the well locations typically varied from about 3 to 10 feet below ground surface which corresponds to approximate elevations of +1 to +8 feet.

4.0 GEOLOGIC HAZARDS

This section summarizes our review of commonly considered geologic hazards and discusses their potential impacts on the planned improvements. The primary geologic hazards which could affect the proposed development include strong seismic ground shaking, potential liquefaction of the sandy fill soils, settlement due to consolidation of the soft Bay Mud, and potentially corrosive soil and groundwater conditions. Other geologic hazards are judged less than significant with regard to the proposed project. Each significant geologic hazard considered is discussed in further detail in the following paragraphs.

4.1 Seismic Shaking

The site will likely experience seismic ground shaking similar to other areas in the seismically active Bay Area. The intensity of ground shaking will depend on the characteristics of the causative fault, distance from the fault, the earthquake magnitude and duration, and site specific geologic conditions. Estimates of peak ground accelerations are based on either deterministic or probabilistic methods.

Deterministic methods use empirical attenuation relations that provide approximate estimates of median peak ground accelerations. A summary of the active faults that could most significantly affect the planning area, their maximum credible magnitude, closest distance to the center of the planning area, and probable peak ground accelerations are summarized in Table 1. The calculated accelerations should only be considered as reasonable estimates. Many factors (soil conditions, orientation to the fault, etc.) can influence the actual ground surface accelerations.

Table 1 – Estimated Peak Ground Accelerations for Principal Active Faults

| Fault | Moment Magnitude for Characteristic Earthquake | Closest Estimated Distance (km) | Median Peak Ground Acceleration (g) |
|---------------|--|------------------------------------|--|
| San Andreas | 8.0 | 10 | 0.30 |
| San Gregorio | 7.4 | 13 | 0.25 |
| Hayward | 7.3 | 17 | 0.21 |
| Rodgers Creek | 7.3 | 33 | 0.14 |
| Calaveras | 6.9 | 40 | 0.10 |

Reference: Caltrans ARS Online v2.3.09 accessed on August, 2017 using $V_{s30} = 180$ m/s.

The potential for strong seismic shaking at the project site is high. Due to their proximity and historic rates of activity, the San Andreas and San Gregorio Faults present the highest potential for severe ground shaking. The significant adverse impact associated with strong seismic shaking is potential damage to the pump station and related improvements. Measures to mitigate the effects of ground shaking should, as a minimum, include using flexible connections where pipelines connect to the new structures and designing new structures to resist seismic loads as discussed in Section 5.1.

4.2 Liquefaction and Related Effects

Liquefaction refers to the sudden, temporary loss of soil strength during strong ground shaking. The strength loss occurs as a result of the build-up of excess pore water pressures and subsequent reduction of effective stress. While liquefaction most commonly occurs in saturated, loose, granular deposits, recent studies indicate that it can also occur in materials with relatively high fines content provided the fines exhibit lower plasticity. The effects of liquefaction can vary from cyclic softening resulting in limited strain potential to flow failure which cause large settlements and lateral ground movements. Lateral spreading refers to a specific type of liquefaction-induced ground failure characterized primarily by horizontal displacement of surficial soil layers as a consequence of liquefaction of a subsurface granular layer (Youd, 1995). Lateral spreads generally move down gentle slopes or slip toward a free face such as an incised river channel.

As shown on Figure 5, regional liquefaction hazard maps indicate the majority of the site is mapped within a zone of very high susceptibility to liquefaction (Association of Bay Area Governments, 2017). The fill encountered in our borings consists of an approximately 9- to 10-foot-thick layer of loose to medium dense sandy soils which contain variable amounts of gravel, clay and silt. We evaluated liquefaction potential for these soils in general accordance with the procedures outlined by Idriss and Boulanger (2010). We assumed a groundwater depth of seven feet below ground surface (approximate elevation of +8 feet) and a peak ground acceleration² (PGA) of 0.51 g. The results of our liquefaction analyses are shown on Figure 6 and indicate the fill is generally susceptible to liquefaction under the design PGA. The analysis further indicates that if liquefaction does occur, post-liquefaction settlements of up to about two inches should be expected. Minimum mitigation measures should include using flexible connections where pipelines connect to the new structures and designing new structures to accommodate the estimated post-liquefaction settlements as discussed in Section 5.3.

4.3 Settlement

Significant settlement can occur when new loads are applied to soft, compressible soils such as the Bay Mud encountered in the project borings. The rate and magnitude of potential settlements are dependent on the new loads that are applied, the presence of drainage layers, the thickness of compressible material, the inherent compressibility properties of the soils, and other factors. There are two modes of settlement of the Bay Mud: primary consolidation and secondary compression. Consolidation settlement often takes decades to complete, whereas secondary compression is generally a fraction of the total settlement but occurs over a much longer time.

Considering the Bay Mud thickness within the project area is less than about 10 feet, and that nearly 70 years has passed since the existing fill was placed, primary consolidation settlement due to the fill placement is expected to be essentially complete. However, additional settlements may be induced due to new structural loads from the planned improvements. We estimated the magnitude of these additional settlements using the preliminary layout shown on Figure 2 and structural loads presented in Table 2. Our analysis assumes the Bay Mud is normally consolidated with a compression index (C_c , strain-based) of 0.31 and recompression index (C_r , strain-based) of 0.05.

² The PGA used for liquefaction analysis is based on the MCE_G peak ground acceleration adjusted for site effects, calculated in accordance with ASCE 7 (ASCE, 2010).

Table 2 – Preliminary Structural Loads

| Structure | Plan Dimensions | Embedment Depth | Contact Pressure |
|---------------------|------------------------|-----------------|------------------|
| Coloma Pump Station | 16.3-ft-diameter | 28 feet | 560 psf |
| Valve Vault | 17.5 feet by 12.3 feet | 8.5 feet | 750 psf |
| Generator Pad | 29.5 feet by 12.0 feet | At Grade | 550 psf |
| Electrical Building | 28.0 feet by 20.0 feet | 14.2 feet | 715 psf |
| Flowmeter Vault | 13.7 feet by 9.0 feet | 8.3 feet | 915 psf |

Reference: Preliminary dimensions and loads based on information provided by Carollo.

Based on the planned excavation depths, new structural loads from underground structures (e.g., the pump station, electrical building, vaults, manholes, etc.) will likely be balanced by the soil that is removed during excavation. Additionally, the pump station will likely be founded on firm bedrock which was encountered at about 20 feet below ground surface in the project borings. Therefore, consolidation settlement due to the proposed underground structures is expected to be negligible. For new above-grade structures founded on shallow foundations, we estimate up to about 2 inches of total settlement may occur due to the new loads. The new structures should be designed to account for the estimated settlements, as discussed further in Section 5.3.

4.4 Corrosive Soils

Corrosive soil can damage buried metallic structures, cause concrete spalling, and deteriorate rebar reinforcement. Per Caltrans Corrosion Guidelines (2012), a soil is considered corrosive if one or more of the following conditions exist:

- Chloride concentration is 500 ppm or greater
- Sulfate concentration is 2,000 ppm or greater
- pH is 5.5 or less

Soil samples collected from both borings at various depths were composited and tested to evaluate pH, electrical resistivity, chloride and sulfate contents. These laboratory test results are presented in Appendix B. The results of our corrosivity testing show the soil has a pH of 7.5, a chloride concentration of 2200 parts per million (ppm), and a sulfate concentration of 190 ppm. The corrosion test results indicate the soils are considered corrosive per Caltrans guidelines.

Minimum mitigation measures should include designing concrete structures in accordance with applicable durability requirements outlined in ACI 318. Metallic components should incorporate protective coatings or other measures aimed at improving corrosion resistance. We recommend that a qualified corrosion engineer be retained to review the laboratory test results and to provide additional mitigation measures as required.

5.0 CONCLUSIONS AND RECOMMENDATIONS

Based on the results of our subsurface exploration, we judge that construction of the proposed pump station and related improvements is feasible from a geotechnical standpoint. Primary geotechnical considerations for the project include: excavation through variable geologic conditions which include loose to medium dense, saturated sandy fill, soft Bay Mud and Franciscan bedrock; providing appropriate temporary support for excavations; providing for proper pipe bedding and backfill for excavations; and designing new structures to account for seismic loads and potential settlement due to liquefaction and/or consolidation of the soft Bay Mud. Additional discussion and recommendations addressing these and other considerations are presented in the following sections.

5.1 Seismic Design

Minimum mitigation of ground shaking includes seismic design of new structures in conformance with the provisions of the most recent edition (2016) of the California Building Code. The magnitude and character of these ground motions will depend on the particular earthquake and the site response characteristics. Based on the interpreted subsurface conditions and proximity of the San Andreas and San Gregorio Faults, we recommend the CBC coefficients and site values shown in Table 3 be used for the design of the new pump station and related improvements.

Table 3 – 2016 California Building Code Seismic Design Criteria

| Parameter | Design Value |
|----------------------------------|--------------|
| Site Class | E |
| Site Latitude | 37.868°N |
| Site Longitude | -122.503°W |
| Spectral Response (short), S_s | 1.500 g |
| Spectral Response (1-sec), S_1 | 0.651 g |
| Site Coefficient, F_a | 0.9 |
| Site Coefficient, F_v | 2.4 |

Reference: USGS US Seismic Design Maps accessed on August 18, 2017.

5.2 Earthwork

Earthwork for the pump station and related improvements should be performed in accordance with the following recommendations:

5.2.1 Subgrade Preparation

Clear pavements, over-sized debris, and organic material from areas to be graded. Debris, rocks larger than six inches, and vegetation are not suitable for structural fill and should be removed from the site. Trees that are located within the building areas should be removed and the root systems excavated. Existing foundations and utilities which are to be

abandoned as part of the work should be removed from structural areas. In non-structural areas, utilities could be abandoned in place in many cases provided cement grout completely fills any void in the utility.

Where structural improvements are planned, the subgrade surface should be scarified to a depth of eight inches, moisture conditioned to slightly above the optimum moisture content, and compacted to at least 90 percent relative compaction. Within pavement areas, the subgrade should be compacted to at least 95 percent relative compaction. Relative compaction refers to the in-place dry density of soil expressed as a percentage of the maximum dry density, as determined by ASTM D1557. Areas exposing bedrock at subgrade elevation need not be scarified and compacted. The subgrade should be firm and unyielding when proof-rolled with heavy, rubber-tired construction equipment. If soft, wet or otherwise unsuitable materials are encountered at subgrade elevation during construction, we will provide supplemental recommendations to address the specific condition.

5.2.2 Excavations

Excavations will generally encounter fill consisting of loose to medium dense, clayey sand over very soft to soft Bay Mud. Based on the borings, weathered Franciscan bedrock will also likely be encountered where excavations extend more than about 20 feet below ground surface. While not encountered in our borings, the backfill around and below the existing pump station may also include relatively permeable materials.

In unsupported excavations, the sandy fill soils will be susceptible to flowing below groundwater and running to fast raveling above groundwater. The Bay Mud will be susceptible to squeezing while the Franciscan bedrock will exhibit firm behavior. Definitions of the various ground behaviors are presented in the Tunnelman's Ground Classification for Soils, Figure 7. In accordance with OSHA soil type designations, the fill and Bay Mud are considered "Type C" soils whereas the Franciscan bedrock is considered "Type B". Temporary support for excavations should be installed to ensure the safety of workers and to reduce the potential for damage to surrounding areas. Shoring and temporary support of excavations is discussed in further detail in Section 5.4

Based on our subsurface exploration, we judge the majority of site excavation can be performed with typical equipment, such as medium-size excavators. However, Franciscan bedrock often contains inclusions and zones of harder, more resistant rock which may require specialized techniques or equipment to excavate (e.g. jackhammers or hydraulic breakers). Therefore, we recommend inclusion of a line item and clear definition for "hard rock excavation" in the project bid documents. If hard rock is encountered during construction which prohibits excavation to the required depths, we should be consulted to observe conditions and revise our recommendations and/or design criteria as appropriate.

5.2.3 Excavation Bottom Stabilization

Based on the fill thicknesses observed during our subsurface exploration, the bottom of excavations for the new improvements may extend through the fill soils and into the underlying Bay Mud. In areas where excavations extend below the top of the Bay Mud or where excavation bottoms are soft, loose, or otherwise unstable, we recommend the excavation bottoms be overexcavated a minimum of 12 inches below the planned invert elevation and backfilled with drain rock. The drain rock should be completely wrapped with a geotextile filter fabric consisting of Mirafi FW300 or an approved equivalent.

5.2.4 Fill Materials

Unless otherwise recommended by SMCSD or the pipe manufacturer, pipe bedding and embedment materials should consist of well-graded sand with 90 to 100 percent of particles passing the No. 4 sieve, and no more than 5 percent finer than the No. 200 sieve. Class 2 aggregate base may also be used provided it conforms to the most recent version of Caltrans Standard Specifications and is compacted as described below. Shovel slicing or other methods should be used to ensure embedment materials are uniformly compacted around the haunches of the pipe. Alternatively, controlled low strength material (CLSM) may be used for pipe bedding and embedment. Provide the minimum bedding thickness beneath the pipe in accordance with the manufacturer's recommendations (typically 3 to 6 inches).

Fill materials used for structural backfill should consist of non-expansive materials that are free of organic matter, have a Liquid Limit of less than 40 (ASTM D 4318), a Plasticity Index of less than 20 (ASTM D 4318), and have a minimum R-value of 20 (California Test 301). The fill material should contain no more than 50 percent of particles passing a No. 200 sieve and should have a maximum particle size of 4 inches. Some of the onsite fill soils may be suitable for re-use as trench backfill. The Bay Mud is not suitable for use as fill and should be removed from the site.

5.2.5 Fill Placement and Compaction

Fill materials should be moisture conditioned to near the optimum moisture content prior to compaction. Properly moisture conditioned fill materials should subsequently be placed in loose, horizontal lifts of 8 inches-thick or less and uniformly compacted to at least 90 percent relative compaction. In pavement areas, the upper 12 inches of backfill should be compacted to at least 95 percent relative compaction. The maximum dry density and optimum moisture content of fill materials should be determined in accordance with ASTM D1557.

5.3 Foundation and Pump Station Structural Design

Design criteria for the new pump station and other underground structures are detailed on Figure 8. A buoyant uplift force will develop when the water level within the structure is lower than the

exterior groundwater level. The design engineer will need to determine the maximum differential between the exterior and interior water levels. Resistance to uplift includes the weight of the structure plus the skin friction on the exterior of the structure. If necessary, the uplift resistance can be increased by structurally extending the foundation beyond the limits of the walls. Alternatively, helical anchors could be utilized to provide uplift resistance.

The walls of the pump station are expected to be restrained at the top and bottom which prevents lateral deflection. This type of wall is subject to a uniform active pressure distribution instead of the equivalent fluid pressure that is typically used for cantilevered walls. In addition, the walls need to withstand seismic and surcharge loading and hydrostatic forces due to potential differential water levels inside and outside of the wet well, as shown on Figure 8. For design of the pump station and other buried structures, we recommend that the groundwater level be taken as equal to the ground surface elevation.

The generator, transformer and other above-grade improvements may be supported on mat slabs provided they are designed to account for settlement due to liquefaction and consolidation of the Bay Mud. This should include up to 3 inches of total settlement and 1.5 inches of differential settlement over a span of 25 feet. If mat slab foundations are utilized, they should be designed using a modulus of subgrade reaction of 200 pci. Mat slabs should be designed using an allowable bearing pressure of 2,000 psf for soil and 4,000 psf for bedrock. Lateral loads for mat slabs can be resisted using a base friction coefficient of 0.35 and a passive resistance of 300 pcf. The slab subgrade should be prepared as discussed under Section 5.2.1. If excavations expose soft, unstable soils beneath the slabs, the bottom of the excavation should be prepared as discussed under Section 5.2.3.

If the new above-grade structures are not capable of accommodating the estimated settlements, they should be supported on deep foundations that extend into bedrock. While various deep foundation systems are feasible, helical piles are suitable for supporting the structural loads and are likely relatively cost-effective as compared to other systems. We estimate the helical piles should achieve vertical load capacities of about 35 kips provided they are advanced to bear on firm bedrock. Helical piles are limited in providing lateral resistance due to their relatively small diameter. Therefore, lateral loads will need to be resisted through base friction and passive resistance of embedded portions of the new structures. Battered helical piles could also be considered if additional lateral capacity is required.

Drilled piers are also an appropriate deep foundation alternative. However, the loose, granular fill soils and soft Bay Mud may result in caving or squeezing conditions and the use of casing, drilling slurry or other means of supporting the pier excavation during drilling and concrete placement should be anticipated. If used, drilled piers should be embedded a minimum of five feet into bedrock and should be designed using an allowable skin friction of 300 psf for soil and 1,000 psf for bedrock to resist vertical loads. Tip resistance should be neglected in calculating the vertical capacity for drilled piers.

The capacity of a drilled pier foundation system to resist lateral loading is a function of the soil type, foundation diameter, pier layout, allowable displacement and other factors. We estimated the lateral capacity of a drilled pier foundation for the new at-grade equipment pad using the computer software *Group 2016* by Ensoft, Inc. and the soil parameters shown in Table 4. Our analysis considered 24-inch-diameter drilled piers with a 1.5-ft-thick mat slab configured as shown in Appendix C and the three loading conditions presented below. The calculated deflections, bending moment and shear for each pile under the various loading conditions are summarized in Appendix C.

Case 1: Estimating the displacements resulting from a total lateral load of 51 kips.

Case 2: Estimating the total lateral load that would result in a displacement of 0.25 inches.

Case 3: Estimating the total lateral load that would result in a displacement of 0.50 inches.

Table 4 – Soil Parameters for Lateral Pile Analysis

| Depth (feet) | General Soil Type | Unit Weight (pcf) | Friction Angle (deg) | Undrained Shear Strength (psf) | Subgrade Modulus (pci) | Strain at 50% Deflection (%) |
|-----------------|----------------------|-------------------------|----------------------------|---|------------------------------|---------------------------------------|
| 0 to 10 | Sandy Soil | 115 | 30 | 0 | 20 | - |
| 10 to 20 | Soft Clay | 95 | 0 | 300 | 30 | 2.0 |
| 20+ | Bedrock | 130 | 0 | 4,000 | 2,000 | 0.5 |

5.4 Temporary Support of Excavations

Temporary support of excavations will be required to ensure the safety of workers and to reduce the potential for failure of the excavation sidewalls and damage to surrounding improvements. While a variety of systems are available, shoring that applies positive pressure and immediate support to the side walls of the excavation will be more effective in controlling ground movements and reducing the risk of damage to nearby utilities and structures. A “watertight” shoring system should be utilized to minimize the need for dewatering which could result in an increase in the effective stress of the overlying fill soils and subsequent settlement of the soft Bay Mud.

The selection, design, installation, monitoring, and removal of temporary shoring should be the responsibility of the Contractor in accordance with their means and methods. The selected support system should be designed to resist lateral pressures from earth, groundwater and construction surcharge loads. As a minimum, shoring systems should be designed based on the criteria provided in Figure 8.

5.5 Instrumentation and Monitoring

Given that deep excavations will be required for construction of the planned improvements, a preconstruction survey should be performed to document the condition of the existing pump station, adjacent apartment building and other nearby existing improvements. The survey should include video documentation of the buildings and surrounding areas and establishing survey control points on the ground surface and nearby structures. The baseline elevations of the monitoring points should be compared with survey readings taken during construction to determine if any ground movements occur.

If construction activities are expected to generate relatively high levels of ground-borne vibrations (e.g. from sheet pile installation, pile driving, etc.), vibration monitoring should be performed to evaluate potential impacts on adjacent structures. The susceptibility of damage to structures due to ground-borne vibrations depends on the type of vibration (i.e. transient or continuous), the distance from the vibration source, the age and condition of the structure, soil and groundwater conditions, the type of construction (e.g. wood-framed, steel, architectural finishes, etc.) and various other factors. A study by Whiffen (1971) established damage thresholds to structures due to continuous vibrations, as summarized in Table 5. While these thresholds may be used for general guidance, project-specific thresholds should be established based on criteria that is developed for specific structures.

Table 5 – Damage Thresholds due to Continuous Vibration

| PPV (in/sec) | Design Value |
|---------------|--|
| 0.4 – 0.6 | Architectural damage and possible minor structural damage |
| 0.2 | Threshold at which there is a risk of architectural damage to normal dwelling houses (houses with plastered walls and ceilings). |
| 0.1 | Virtually no risk of architectural damage to normal buildings |
| 0.08 | Recommended upper limit of vibration to which ruins and ancient monuments should be subjected. |
| 0.006 – 0.019 | Vibration unlikely to cause damage |

5.6 New Pavements

New pavements will be required for the pump station driveway and for trenches that extend into traffic areas. We have provided preliminary pavement design in accordance with Caltrans procedures for flexible pavement (Caltrans, 2015). We assumed Traffic Index values ranging from 4 to 7 depending on the expected traffic loads for a twenty-year design life. For our preliminary design, we assumed an R-value of 20 and 50 which are generally consistent with R-values for select fill and Class 2 aggregate subbase, respectively. During construction, we should test the backfill materials to confirm the R-value of the backfill material is consistent with our assumed values. The preliminary recommended pavement sections are presented in Table 6.

Table 6 – Preliminary Asphalt-Concrete Pavement Sections

| Traffic Index | Select Fill Backfill (R-Value = 20) | | Class 2 Aggregate Subbase (R-Value = 50) | |
|---------------|--|--|---|--|
| | Asphalt Thickness (inches) | Class 2 Aggregate Base Thickness (inches) | Asphalt Thickness (inches) | Class 2 Aggregate Base Thickness (inches) |
| 4 | 3.0 | 5.0 | 2.5 | 4.0 |
| 5 | 3.5 | 7.0 | 3.0 | 5.0 |
| 6 | 4.0 | 9.0 | 3.5 | 6.0 |
| 7 | 5.0 | 10.0 | 4.0 | 7.0 |

The subgrade in new pavement areas should be prepared as discussed under Section 5.2.1. The Class 2 aggregate base and asphalt-concrete should conform to the most recent version of Caltrans Standard Specifications and should be compacted to at least 95% relative compaction. Additionally, the aggregate base should be firm and unyielding under heavy, rubber-tired construction equipment. If heavier truck traffic or “superior” performance is desired, the thickness of the aggregate base and asphalt thickness may be increased.

6.0 SUPPLEMENTAL GEOTECHNICAL SERVICES

We must review the plans and specifications when they are nearing completion to confirm that the intent of our recommendations has been incorporated and to provide supplemental recommendations as needed. During construction, we must inspect geotechnical items relating to earthwork, foundations and new pavement construction. We should observe the excavations for the new pump station and other improvements, foundation construction, proper moisture conditioning of soils, fill placement and compaction, and other geotechnical-related work items.

7.0 LIMITATIONS

We believe this report has been prepared in accordance with generally accepted geotechnical engineering practices in Marin County at the time the report was prepared. This report has been prepared for the exclusive use of the project Owner and/or their assignees specifically for this project. No other warranty, expressed or implied, is made. Our evaluations and recommendations are based on the data obtained during our subsurface exploration program and our experience with soils in this geographic area.

8.0 LIST OF REFERENCES

American Society of Civil Engineers (ASCE) (2010), "Minimum Design Loads for Buildings and Other Structures" (2010 ASCE-7), Structural Engineering Institute of the American Society of Civil Engineers.

American Concrete Institute, "318-14: Building Code Requirements for Structural Concrete and Commentary".

American Society for Testing and Materials, (2009) "2009 Annual Book of ASTM Standards, Section 4, Construction, Volume 4.08, Soil and Rock; Dimension Stone; Geosynthetics," ASTM, Philadelphia.

California Building Code, 2016 Edition, California Building Standards Commission/International Conference of Building Officials, Whittier, California.

California Code of Regulations, Title 22.

California Department of Transportation (Caltrans) (2015), 2015 Standard Specifications.

California Department of Transportation (Caltrans) (2015, Highway Design Manual

California Department of Transportation (Caltrans) Division of Engineering Services, Materials Engineering and Testing Services, Corrosion and Structural Concrete, Field Investigation Branch, "Corrosion Guidelines, Version 2.0", November, 2012.

California Department of Transportation (Caltrans) (2015), "Caltrans ARS Online, V 2.3.06" (web-based deterministic acceleration response spectra calculator tool), http://dap3.dot.ca.gov/ARS_Online/, accessed March 20, 2016.

California Division of Mines and Geology, "Geology of the Tiburon Peninsula, Sausalito, and Adjacent Areas, Marin County, California." California Department of Mines and Geology, (Scale 1:12,000)", 1976.

Cambria Environmental Technology, "Groundwater Monitoring Report – Special Event – December, 2002, Shell-branded Service Station, 2901 Bridgeway Avenue, Sausalito, California", 2003.

Carollo, "Sausalito-Marin City Sanitary District, Coloma Pump Station Improvements Project, Sausalito California (50% Submittal)", dated April, 2019.

DCM Consulting, Inc., "Technical Memorandum, Preliminary Geotechnical and Trenchless Engineering Evaluation for Planning and Preliminary Design of Scotties Wet Weather Pump Station and Highway Booster Pump Station Improvements, Sausalito-Marin City Sanitary District, Sausalito, California", November 25, 2014.

Idriss, I.M. & Boulanger, R.W. "Soil Liquefaction during Earthquakes", Earthquake Engineering Research Institute Monograph 12, 2008.

Idriss, I.M. & Boulanger, R.W. "SPT-Based Liquefaction Triggering Procedures" Department of Civil and Environmental Engineering, College of Engineering, University of California at Davis, UCD/GCM-10/02, December 2010.


Occupational Safety and Health Administration (OSHA)(2005), Title 29 Code of Federal Regulations, Part 1926 (www.OSHA.gov).

United States Geological Survey, "California San Francisco Quadrangle", 1895.

United States Geological Survey, "California San Francisco Quadrangle", 1897.

United States Geological Survey, "California San Francisco North Quadrangle", 1947, 1950, 1956, 1993, 1995 and 2015.


Whiffen, A. C. 1971. *A survey of traffic-induced vibrations*. (Report LR419.) Crowthorne, Berkshire, England: United Kingdom Department of Environment, Road Research Laboratory




SITE LOCATION
(NO SCALE)



REFERENCE: USGS, Point Bonita, San Francisco North, San Rafael, and San Quentin Quadrangle, 7.5' Series, 2015.

| | | | | | |
|--|-----------------------|---------------------------|--|------------------|-------------|
|  <p>MILLER PACIFIC ENGINEERING GROUP</p> <p>A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED</p> <p>FILENAME: 2213.004 Figures.dwg</p> | 504 Redwood Blvd. | SITE LOCATION MAP | | | |
| | Suite 220 | SMCSD Coloma Pump Station | | | |
| Novato, CA 94947 | Sausalito, California | | | Drawn <u>RCA</u> | 1 FIGURE |
| T 415 / 382-3444 | | | | Checked _____ | |
| F 415 / 382-3450 | Project No. 2213.004 | | | Date: 8/20/2017 | |
| www.millerpac.com | | | | | |



SITE PLAN
(SCALE: 1" = 10'-0")

LEGEND:




APPROXIMATE LOCATION OF TEST BORING BY MILLER PACIFIC, 2017

REFERENCE: Carollo, "Sausalito-Marín City Sanitary District, Coloma Pump Station Improvements Project, Sheet C02 (50% Submittal), dated April 2019.



SCALE



MPEG
MILLER PACIFIC
ENGINEERING GROUP

A CALIFORNIA CORPORATION, © 2016, ALL RIGHTS RESERVED
FILE: 2213.004 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

SITE PLAN


SMCSD Coloma Pump Station
Sausalito, California

Project No. 2213.004

Date: 8/24/2017

Designed
Drawn
Checked
RCA

2
FIGURE



REGIONAL GEOLOGIC MAP

(NOT TO SCALE)



LEGEND

- Qaf** **Artificial Fill** - Deposits of rock, soil, garbage and debris placed by man on natural surfaces, mostly for engineering purposes. Highly variable from place to place as to composition, degree of compaction, etc.
- Qm** **Bay Mud** - Marshlands and mudflats bordering San Francisco and San Pablo Bays. Deposits of unconsolidated, low density, semi-fluid, highly compressible silty clay.
- Qc** **Colluvium** - Unconsolidated and unsorted soil material and weathered rock fragments accumulated on or at the base of slopes by natural gravitational forces.
- fm** **Franciscan Melange** - A tectonic mixture of resistant rock types, principally sandstone, greenstone, chert, and serpentine, embedded in a matrix of pervasively sheared rock material

Reference: Rice, Salem J., Smith, Theodore C., (1976), "Geology of the Tiburon Peninsula, Sausalito, and Adjacent Areas, Marin County, California." California Department of Mines and Geology, Scale 1:12,000.



A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
 FILENAME: 2213.004 Figures.dwg

504 Redwood Blvd.
 Suite 220
 Novato, CA 94947
 T 415 / 382-3444
 F 415 / 382-3450
 www.millerpac.com

REGIONAL GEOLOGIC MAP

SMCSD Coloma Pump Station
 Sausalito, California


Drawn NGK
 Checked

3

FIGURE

Project No. 2213.004

Date: 8/20/2017



DATA SOURCE:

1) U.S. Geological Survey, U.S. Department of the Interior, "Earthquake Outlook for the San Francisco Bay Region 2014-2043", Map of Known Active Faults in the San Francisco Bay Region, Fact Sheet 2016-3020, Revised August 2016 (ver. 1.1).



MILLER PACIFIC
ENGINEERING GROUP

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 2213.004 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

ACTIVE FAULT MAP

SMCSD Coloma Pump Station
Sausalito, California

Drawn NGK
Checked _____

4

FIGURE

Project No. 2213.004

Date: 8/20/2017



LIQUEFACTION SUSCEPTIBILITY

(NO SCALE)

Liquefaction Susceptibility Hazard

- Very High Susceptibility
- High Susceptibility
- Moderate Susceptibility
- Low Susceptibility
- Very Low Susceptibility

REFERENCE: Association of Bay Area Governments (<http://gis.abag.ca.gov/website/Hazards/?hlyr=liqSusceptibility>), accessed August 20, 2017.



MILLER PACIFIC
ENGINEERING GROUP

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 2213.004 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

LIQUEFACTION SUSCEPTIBILITY MAP

SMCSD Coloma Pump Station
Sausalito, California

Drawn RCA
Checked _____


Project No. 2213.004

Date: 8/20/2017

5

FIGURE

Liquefaction Analysis
(Idriss, I.M. & Boulanger, R.W., 2008 & 2010)



A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 2213.004 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

LIQUEFACTION ANALYSES

SMCSD Coloma Pump Station
Sausalito, California

Project No. 2213.004

Date: 8/20/2017

Drawn RCA
Checked _____

6

FIGURE

Tunnelman's Ground Classification for Soils¹

| Classification | | Behavior | Typical Soil Types |
|----------------|---|--|--|
| Firm | | Heading can be advanced without initial support, and final lining can be constructed before ground starts to move. | Loess above water table; hard clay, marl, cemented sand and gravel when not highly overstressed. |
| Raveling | Slow raveling ----- Fast raveling | Chunks or flakes of material begin to drop out of the arch or walls sometime after the ground has been exposed, due to loosening or to overstress and "brittle" fracture (ground separates or breaks along distinct surfaces, opposed to squeezing ground). In fast raveling ground, the process starts within a few minutes, otherwise the ground is slow raveling. | Residual soils or sand with small amounts of binder may be fast raveling below the water table, slow raveling above. Stiff fissured clays may be slow or fast raveling depending upon degree of overstress. |
| Squeezing | | Ground squeezes or extrudes plastically into tunnel, without visible fracturing or loss of continuity, and without perceptible increase in water content. Ductile, plastic yield and flow due to overstress. | Ground with low frictional strength. Rate of squeeze depends on degree of overstress. Occurs at shallow to medium depth in clay of very soft to medium consistency. Stiff to hard clay under high cover may move in combination of raveling at excavation surface and squeezing at depth behind surface. |
| Running | Cohesive-running ----- Running | Granular materials without cohesion are unstable at a slope greater than their angle of repose (+/- 30° – 35°). When exposed at steeper slopes they run like granulated sugar or dune sand until the slope flattens to the angle of repose. | Clean, dry granular materials. Apparent cohesion in moist sand, or weak cementation in any granular soil, may allow the material to stand for a brief period of raveling before it breaks down and runs. Such behavior is cohesive-running. |
| Flowing | | A mixture of soil and water flows into the tunnel like a viscous fluid. The material can enter the tunnel from the invert as well as from the face, crown, and walls, and can flow for great distances, completely filling the tunnel in some cases. | Below the water table in silt, sand, or gravel without enough clay content to give significant cohesion and plasticity. May also occur in highly sensitive clay when such material is disturbed. |
| Swelling | | Ground absorbs water, increases in volume, and expands slowly into the tunnel. | Highly preconsolidated clay with plasticity index in excess of about 30, generally containing significant percentages of montmorillonite. |

¹ Modified by Heuer (1974) from Terzaghi (1950)



A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 2213.004 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

TUNNELMAN'S GROUND CLASSIFICATION FOR SOILS

SMCSD Coloma Pump Station
Sausalito, California


Project No. 2213.004

Date: 8/20/2017

Drawn RCA
Checked _____

7

FIGURE



NOTES:

1. Assume groundwater is at the ground surface for design of permanent structures.
2. Surge pressures shown are based on H2O Traffic Loads. Other surge loads (e.g. due to construction traffic, soil stockpiles, structural loads, etc) may occur and should be applied by the designer as applicable.

APPENDIX A

SUBSURFACE EXPLORATION AND GEOTECHNICAL LABORATORY TESTING

A. SUBSURFACE EXPLORATION

We explored subsurface conditions with two exploratory borings drilled with track-mounted equipment on July 12, 2017 at the approximate locations shown on the Site Plan, Figure 2. The exploration was conducted under the technical supervision of our Field Geologist who examined and logged the soil materials encountered and obtained samples. The subsurface conditions encountered in the test borings are summarized and presented on the Boring Logs, Figures A-3 through A-5.

















“Undisturbed” samples were obtained using a 3-inch diameter, split-barrel Modified California Sampler with 2.5 by 6-inch tube liners or a Standard Penetration Test (SPT) Sampler. The samplers were driven by a 140-pound hammer at a 30-inch drop. The number of blows required to drive the samplers 18 inches was recorded and is reported on the boring logs as blows per foot for the last 12 inches of driving. The samples obtained were examined in the field, sealed to prevent moisture loss, and transported to our laboratory

B. GEOTECHNICAL LABORATORY TESTING

We conducted geotechnical laboratory tests on selected intact samples to classify soils and to estimate engineering properties. The following laboratory tests were conducted in general accordance with the ASTM standard test method cited:

- Laboratory Determination of Water (Moisture Content) of Soil, Rock, and Soil-Aggregate Mixtures, ASTM D 2216
- Density of Soil in Place by the Drive-Cylinder Method, ASTM D 2937
- Unconfined Compressive Strength of Cohesive Soil, ASTM D 2166
- Amount of Material in Soils Finer than No. 200 (75- μ m) Sieve, ASTM D1140
- Corrosivity as pH, EPA 904.
- Conductivity, SM 2510B
- Chlorides and Sulfates, EPA 300

The moisture content, dry density, amount of material passing a No. 200 sieve and unconfined compression test results are shown on the exploratory boring logs. The exploratory boring logs, description of soils encountered and the laboratory test data reflect conditions only at the location of the boring at the time they were excavated or retrieved. Conditions may differ at other locations and may change with the passage of time due to a variety of causes including natural weathering, climate and changes in surface and subsurface drainage.






| MAJOR DIVISIONS | | SYMBOL | | DESCRIPTION |
|--|------------------------------------|--------|---|--|
| COARSE GRAINED SOILS over 50% sand and gravel | CLEAN GRAVEL | GW |  | Well-graded gravels or gravel-sand mixtures, little or no fines |
| | | GP |  | Poorly-graded gravels or gravel-sand mixtures, little or no fines |
| | GRAVEL with fines | GM |  | Silty gravels, gravel-sand-silt mixtures |
| | | GC |  | Clayey gravels, gravel-sand-clay mixtures |
| | CLEAN SAND | SW |  | Well-graded sands or gravelly sands, little or no fines |
| | | SP |  | Poorly-graded sands or gravelly sands, little or no fines |
| | SAND with fines | SM |  | Silty sands, sand-silt mixtures |
| | | SC |  | Clayey sands, sand-clay mixtures |
| FINE GRAINED SOILS over 50% silt and clay | SILT AND CLAY liquid limit <50% | ML |  | Inorganic silts and very fine sands, rock flour, silty or clayey fine sands or clayey silts with slight plasticity |
| | | CL |  | Inorganic clays of low to medium plasticity, gravelly clays, sandy clays, silty clays, lean clays |
| | | OL |  | Organic silts and organic silt-clays of low plasticity |
| | SILT AND CLAY liquid limit >50% | MH |  | Inorganic silts, micaceous or diatomaceous fine sands or silts, elastic silts |
| | | CH |  | Inorganic clays of high plasticity, fat clays |
| | | OH |  | Organic clays of medium to high plasticity |
| HIGHLY ORGANIC SOILS | | PT |  | Peat, muck, and other highly organic soils |
| ROCK | | |  | Undifferentiated as to type or composition |

KEY TO BORING AND TEST PIT SYMBOLS

CLASSIFICATION TESTS

| | |
|------|-------------------------------|
| PI | PLASTICITY INDEX |
| LL | LIQUID LIMIT |
| SA | SIEVE ANALYSIS |
| HYD | HYDROMETER ANALYSIS |
| P200 | PERCENT PASSING NO. 200 SIEVE |
| P4 | PERCENT PASSING NO. 4 SIEVE |

SAMPLER TYPE

| | | | |
|---|----------------------------|---|--------------------------|
|  | MODIFIED CALIFORNIA |  | HAND SAMPLER |
|  | STANDARD PENETRATION TEST |  | ROCK CORE |
|  | THIN-WALLED / FIXED PISTON | X | DISTURBED OR BULK SAMPLE |

NOTE: Test boring and test pit logs are an interpretation of conditions encountered at the excavation location during the time of exploration. Subsurface rock, soil or water conditions may vary in different locations within the project site and with the passage of time. Boundaries between differing soil or rock descriptions are approximate and may indicate a gradual transition.

STRENGTH TESTS

| | |
|----------------------------------|-----------------------------------|
| TV | FIELD TORVANE (UNDRAINED SHEAR) |
| UC | LABORATORY UNCONFINED COMPRESSION |
| TXCU | CONSOLIDATED UNDRAINED TRIAXIAL |
| TXUU | UNCONSOLIDATED UNDRAINED TRIAXIAL |
| UC, CU, UU = 1/2 Deviator Stress | |

SAMPLER DRIVING RESISTANCE

Modified California and Standard Penetration Test samplers are driven 18 inches with a 140-pound hammer falling 30 inches per blow. Blows for the initial 6-inch drive seat the sampler. Blows for the final 12-inch drive are recorded onto the logs. Sampler refusal is defined as 50 blows during a 6-inch drive. Examples of blow records are as follows:

| | |
|-------|---|
| 25 | sampler driven 12 inches with 25 blows after initial 6-inch drive |
| 85/7" | sampler driven 7 inches with 85 blows after initial 6-inch drive |
| 50/3" | sampler driven 3 inches with 50 blows during initial 6-inch drive or beginning of final 12-inch drive |



A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 2213.004 BL.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

SOIL CLASSIFICATION CHART

SMCSD Coloma Pump Station
Sausalito, California

Drawn NGK
Checked

A-1
FIGURE

Project No. 2213.004

Date: 8/2/2017

FRACTURING AND BEDDING

Fracture Classification

Crushed
Intensely fractured
Closely fractured
Moderately fractured
Widely fractured
Very widely fractured

Spacing

less than 3/4 inch
3/4 to 2-1/2 inches
2-1/2 to 8 inches
8 to 24 inches
2 to 6 feet
greater than 6 feet

Bedding Classification

Laminated
Very thinly bedded
Thinly bedded
Medium bedded
Thickly bedded
Very thickly bedded

HARDNESS

Low
Moderate
Hard
Very hard

Carved or gouged with a knife
Easily scratched with a knife, friable
Difficult to scratch, knife scratch leaves dust trace
Rock scratches metal

STRENGTH

Friable
Weak
Moderate
Strong
Very strong

Crumbles by rubbing with fingers
Crumbles under light hammer blows
Indentations <1/8 inch with moderate blow with pick end of rock hammer
Withstands few heavy hammer blows, yields large fragments
Withstands many heavy hammer blows, yields dust, small fragments

WEATHERING

| | |
|----------|--|
| Complete | Minerals decomposed to soil, but fabric and structure preserved |
| High | Rock decomposition, thorough discoloration, all fractures are extensively coated with clay, oxides or carbonates |
| Moderate | Fracture surfaces coated with weathering minerals, moderate or localized discoloration |
| Slight | A few stained fractures, slight discoloration, no mineral decomposition, no affect on cementation |
| Fresh | Rock unaffected by weathering, no change with depth, rings under hammer impact |

NOTE: Test boring and test pit logs are an interpretation of conditions encountered at the location and time of exploration. Subsurface rock, soil and water conditions may differ in other locations and with the passage of time.



MILLER PACIFIC
ENGINEERING GROUP

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 2213.004 BL.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

ROCK CLASSIFICATION CHART

SMCSD Coloma Pump Station
Sausalito, California

Drawn _____
Checked _____
NGK

A-2
FIGURE

Project No. 2213.004

Date: 8/2/2017

| DEPTH meters feet | | BORING 1 | | BLOWS / FOOT (1) | DRY UNIT WEIGHT pcf (2) | MOISTURE CONTENT (%) | SHEAR STRENGTH psf (3) | OTHER TEST DATA | DRILLING RATE (FT/MIN.) |
|-------------------------|---|------------|--|------------------|----------------------------|-------------------------|---------------------------|-----------------|----------------------------|
| SAMPLE | | SYMBOL (4) | EQUIPMENT: Track-Mounted Drill Rig with 4.0-inch Solid Flight Auger DATE: 7/12/17 ELEVATION: 15 - feet* *REFERENCE: Google Earth, 2016 | | | | | | |
| 0 | 0 | | Sandy Clayey GRAVEL (GC) light brown, dry to slightly moist, medium dense, gravel-sized chert, sandstone and shale fragments [Fill] | | | | | | |
| 1 | | | Clayey SAND with Gravel (SC) brown and gray, moist, medium dense, fine to coarse grained [Fill] | 32 | 120 | 8.6 | | P200 29.5 | |
| 5 | | | | | | | | | |
| 2 | | | | 10 | 123 | 12 | | | |
| 3 | | | | | | | | | |
| 10 | | | Sandy CLAY (CH) greenish-brown, moist, soft, medium to high plasticity [Bay Mud] | 5 | 110 | 19.5 | UC 250 | | |
| 15 | | | | | | | | | |
| 5 | | | Silty CLAY (CH) dark gray, wet, very soft, high plasticity abundant organics [Bay Mud] | 3 | 52 | 84.4 | UC 325 | | |
| 6 | | | | | | | | | |
| 20 | | | Sandstone mottled gray, brown and orange, moderate hardness, moderate strength, moderately to highly weathered [Bedrock] | | | | | | |

▽ Water level encountered during drilling
▼ Water level measured after drilling

NOTES: (1) UNCORRECTED FIELD BLOW COUNTS
(2) METRIC EQUIVALENT DRY UNIT WEIGHT $\text{kN/m}^3 = 0.1571 \times \text{DRY UNIT WEIGHT (pcf)}$
(3) METRIC EQUIVALENT STRENGTH $(\text{kPa}) = 0.0479 \times \text{STRENGTH (psf)}$
(4) GRAPHIC SYMBOLS ARE ILLUSTRATIVE ONLY



A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 2213.004 BL.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

BORING LOG

SMCSD Coloma Pump Station
Sausalito, California



Drawn NGK
Checked

A-3
FIGURE

Project No. 2213.004

Date: 8/2/2017

| DEPTH meters feet | SAMPLE | SYMBOL (4) | BORING 1 (CONTINUED) | BLOWS / FOOT (1) | DRY UNIT WEIGHT pcf (2) | MOISTURE CONTENT (%) | SHEAR STRENGTH psf (3) | OTHER TEST DATA | DRILLING RATE (MIN/FT) |
|-------------------------|--------|------------|---|------------------|----------------------------|-------------------------|---------------------------|-----------------|---------------------------|
| | | | | | | | | | |
| 20 | | | Sandstone mottled gray, brown and orange, moderate hardness, moderate strength, moderately to highly weathered [Bedrock] | 92 | 123 | 14.9 | | | |
| 7 | | | | | | | | | |
| 25 | | | grades to strong | 50/3" | | | | | |
| 8 | | | Bottom of boring at 26.0 feet Groundwater encountered at 12.0 feet during drilling | | | | | | |
| 9 | | | | | | | | | |
| 30 | | | | | | | | | |
| 10 | | | | | | | | | |
| 35 | | | | | | | | | |
| 11 | | | | | | | | | |
| 12 | | | | | | | | | |
| 40 | | | | | | | | | |

 Water level encountered during drilling
 Water level measured after drilling

NOTES: (1) UNCORRECTED FIELD BLOW COUNTS
 (2) METRIC EQUIVALENT DRY UNIT WEIGHT $\text{kN/m}^3 = 0.1571 \times \text{DRY UNIT WEIGHT (pcf)}$
 (3) METRIC EQUIVALENT STRENGTH $(\text{kPa}) = 0.0479 \times \text{STRENGTH (psf)}$
 (4) GRAPHIC SYMBOLS ARE ILLUSTRATIVE ONLY



A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
 FILENAME: 2213.004 BL.dwg

504 Redwood Blvd.
 Suite 220
 Novato, CA 94947
 T 415 / 382-3444
 F 415 / 382-3450
 www.millerpac.com

BORING LOG

SMCS D Coloma Pump Station
 Sausalito, California

Drawn _____
 Checked _____
 NGK

A-4
 FIGURE

Project No. 2213.004

Date: 8/2/2017

| DEPTH | | SAMPLE | SYMBOL (4) | BORING 2 | | BLOWS / FOOT (1) | DRY UNIT WEIGHT pcf (2) | MOISTURE CONTENT (%) | SHEAR STRENGTH psf (3) | OTHER TEST DATA | DRILLING RATE (FT/MIN.) |
|--------|------|--------|------------|---|-------|------------------|-------------------------|----------------------|------------------------|-----------------|-------------------------|
| meters | feet | | | EQUIPMENT: | DATE: | | | | | | |
| | 0 | | | Track-Mounted Drill Rig with 4.0-inch Solid Flight Auger | | | | | | | |
| | | | | 7/12/17 | | | | | | | |
| | | | | 15 - feet* | | | | | | | |
| | | | | Google Earth, 2016 | | | | | | | |
| | 0 | | | Clayey SAND with Gravel (SC) | | | | | | | |
| | | | | brown with yellow and gray mottling, moist, medium dense, fine to coarse sand, subangular gravel [Fill] | | | | | | | |
| | 1 | | | grades loose | | 20 | 121 | 8.8 | | | |
| | 5 | | | | | 7 | 117 | 14.9 | UC 700 | P200 41.0 | |
| | 2 | | | SILTY CLAY (CH) | | | | | | | |
| | | | | gray, wet, soft, high plasticity clay, trace sand and organics [Bay Mud] | | 8 | 107 | 22.6 | UC 525 | | |
| | 3 | | | grades very soft, saturated | | 7 | | | | | |
| | 10 | | | | | | | | | | |
| | 4 | | | | | | | | | | |
| | 15 | | | | | 3 | 50 | 84.2 | UC 350 | | |
| | 5 | | | Bottom of boring at 16.5 feet. | | | | | | | |
| | | | | Groundwater encountered at 12.5 feet during drilling. | | | | | | | |
| | 6 | | | | | | | | | | |
| | 20 | | | | | | | | | | |

▽ Water level encountered during drilling
▼ Water level measured after drilling

NOTES: (1) UNCORRECTED FIELD BLOW COUNTS
(2) METRIC EQUIVALENT DRY UNIT WEIGHT $\text{kN/m}^3 = 0.1571 \times \text{DRY UNIT WEIGHT (pcf)}$
(3) METRIC EQUIVALENT STRENGTH $(\text{kPa}) = 0.0479 \times \text{STRENGTH (psf)}$
(4) GRAPHIC SYMBOLS ARE ILLUSTRATIVE ONLY



A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 2213.004 BL.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

BORING LOG

SMCSD Coloma Pump Station
Sausalito, California

Project No. 2213.004

Date: 8/2/2017

Drawn NGK
Checked

A-5
FIGURE

APPENDIX B
ENVIRONMENTAL LABORATORY TEST RESULTS



Report Date: July 26, 2017

Laboratory Report

Eric Dabanian

Miller Pacific Engineering - Novato

504 Redwood Blvd., Suite 220

Novato, CA 94947

Project Name: **Carollo - Coloma Pump Station** **2213-004**

Lab Project Number: **7071401**

This 14 page report of analytical data has been reviewed and approved for release.

Michele Peters

Laboratory Director



Volatile Hydrocarbons by GC/MS

| Lab# | Sample ID | Compound Name | Result (µg/kg) | RDL (µg/kg) |
|------------|--|-----------------------------------|----------------|-------------|
| 7071401-01 | B1 3.5', 5.5', 10.5' & 15.5' B2 3.5', 6', 11.5' & 15.5' | Gasoline | ND | 500 |
| | | Dichlorodifluoromethane (F-12) | ND | 2.0 |
| | | Chloromethane | ND | 2.0 |
| | | Vinyl chloride | ND | 2.0 |
| | | Chloroethane (CE) | ND | 2.0 |
| | | Bromomethane | ND | 2.0 |
| | | Trichlorofluoromethane (F-11) | ND | 2.0 |
| | | Trichlorotrifluoroethane (F-113) | ND | 2.0 |
| | | 1,1-Dichloroethene (1,1-DCE) | ND | 2.0 |
| | | Methylene chloride | ND | 2.0 |
| | | trans-1,2-Dichloroethene | ND | 2.0 |
| | | 1,1-Dichloroethane (1,1-DCA) | ND | 2.0 |
| | | cis-1,2-Dichloroethene (c1,2-DCE) | ND | 2.0 |
| | | 2,2-Dichloropropane | ND | 2.0 |
| | | Chloroform (THM1) | ND | 2.0 |
| | | Bromochloromethane | ND | 2.0 |
| | | 1,1,1-Trichloroethane (TCA) | ND | 2.0 |
| | | 1,2-Dichloroethane (EDC) | ND | 2.0 |
| | | 1,1-Dichloropropene | ND | 2.0 |
| | | Carbon tetrachloride | ND | 2.0 |
| | | Benzene | ND | 2.0 |
| | | Trichloroethene (TCE) | ND | 2.0 |
| | | 1,2-Dichloropropane (DCP) | ND | 2.0 |
| | | Dibromomethane | ND | 2.0 |
| | | Bromodichloromethane (THM2) | ND | 2.0 |
| | | cis-1,3-Dichloropropene | ND | 2.0 |
| | | Toluene | ND | 2.0 |
| | | 1,1,2-Trichloroethane | ND | 2.0 |
| | | 1,3-Dichloropropane | ND | 2.0 |
| | | Dibromochloromethane (THM3) | ND | 2.0 |
| | | Tetrachloroethene (PCE) | ND | 2.0 |
| | | 1,2-Dibromoethane (EDB) | ND | 2.0 |
| | | Chlorobenzene | ND | 2.0 |
| | | 1,1,1,2-Tetrachloroethane | ND | 2.0 |
| | | Ethylbenzene | ND | 2.0 |
| | | m,p-Xylene | ND | 2.0 |
| | | Styrene | ND | 2.0 |
| | | o-Xylene | ND | 2.0 |
| | | Bromoform (THM4) | ND | 2.0 |
| | | 1,1,2,2-Tetrachloroethane | ND | 2.0 |
| | | Isopropylbenzene | ND | 2.0 |
| | | 1,2,3-Trichloropropane | ND | 2.0 |
| | | Bromobenzene | ND | 2.0 |
| | | n-Propyl Benzene | ND | 2.0 |
| | | 2-Chlorotoluene | ND | 2.0 |
| | | 4-Chlorotoluene | ND | 2.0 |
| | | 1,3,5-Trimethylbenzene | ND | 2.0 |



Volatile Hydrocarbons by GC/MS

| Lab# | Sample ID | Compound Name | Result (µg/kg) | RDL (µg/kg) | |
|----------------------|---|--------------------------------|----------------|----------------------|--|
| 7071401-01 | B1 3.5', 5.5', 10.5' & 15.5' B2 3.5', 6', 11.5' & 15.5' | tert-Butylbenzene | ND | 2.0 | |
| | | 1,2,4-Trimethylbenzene | ND | 2.0 | |
| | | sec-Butylbenzene | ND | 2.0 | |
| | | 1,3-Dichlorobenzene | ND | 2.0 | |
| | | 1,4-Dichlorobenzene | ND | 2.0 | |
| | | 1,2-Dichlorobenzene | ND | 2.0 | |
| | | p-Isopropyltoluene | ND | 2.0 | |
| | | n-Butylbenzene | ND | 2.0 | |
| | | 1,2-Dibromo-3-chloropropane | ND | 2.0 | |
| | | 1,2,4-Trichlorobenzene | ND | 2.0 | |
| | | Naphthalene | ND | 2.0 | |
| | | Hexachlorobutadiene | ND | 2.0 | |
| | | 1,2,3-Trichlorobenzene | ND | 2.0 | |
| | | Tertiary Butyl Alcohol (TBA) | ND | 25 | |
| | | Methyl tert-Butyl Ether (MTBE) | ND | 2.0 | |
| | | Di-isopropyl Ether (DIPE) | ND | 2.0 | |
| | | Ethyl tert-Butyl Ether (ETBE) | ND | 2.0 | |
| | | Tert-Amyl Methyl Ether (TAME) | ND | 2.0 | |
| Surrogates | | Result (µg/kg) | % Recovery | Acceptance Range (%) | |
| Dibromofluoromethane | | 53.1 | 107 | 70-130 | |
| Toluene-d8 | | 46.5 | 94 | 70-130 | |
| 4-Bromofluorobenzene | | 47.9 | 96 | 70-130 | |
| Date Sampled: | 07/12/17 | Date Analyzed: | 07/14/17 | QC Batch: B016854 | |
| Date Received: | 07/14/17 | Method: | EPA 8260B | | |

TPH Diesel & Motor Oil

| Lab# | Sample ID | Compound Name | Result (mg/kg) | RDL (mg/kg) |
|--|---|---------------|----------------|-------------|
| 7071401-01 | B1 3.5', 5.5', 10.5' & 15.5' B2 3.5', 6', 11.5' & 15.5' | Diesel | ND | 5.0 |
| | | Motor Oil | ND | 50 |
| Date Sampled: 07/12/17 Date Analyzed: 07/20/17 QC Batch: B016849 | | | | |
| Date Received: 07/14/17 Method: EPA 8015B | | | | |



Corrosivity as pH

| Lab# | Sample ID | Compound Name | Result (pH Units) | RDL (pH Units) |
|------------|--|---------------|-------------------|----------------|
| 7071401-01 | B1 3.5', 5.5', 10.5' & 15.5' B2 3.5', 6', 11.5' & 15.5' | pH | 7.52 | 1.00 |

| | | | | |
|----------------|----------|----------------|----------|-------------------|
| Date Sampled: | 07/12/17 | Date Analyzed: | 07/18/17 | QC Batch: B016885 |
| Date Received: | 07/14/17 | Method: | EPA 9040 | |

CAM Metals

| Lab# | Sample ID | Compound Name | Result (mg/kg) | RDL (mg/kg) |
|------------|--|-----------------|----------------|-------------|
| 7071401-01 | B1 3.5', 5.5', 10.5' & 15.5' B2 3.5', 6', 11.5' & 15.5' | Antimony (Sb) | ND | 5.0 |
| | | Arsenic (As) | 5.7 | 1.5 |
| | | Barium (Ba) | 110 | 2.0 |
| | | Beryllium (Be) | ND | 0.50 |
| | | Cadmium (Cd) | ND | 0.50 |
| | | Chromium (Cr) | 64 | 6.0 |
| | | Cobalt (Co) | 12 | 1.5 |
| | | Copper (Cu) | 25 | 2.0 |
| | | Lead (Pb) | 18 | 3.0 |
| | | Molybdenum (Mo) | ND | 1.0 |
| | | Nickel (Ni) | 89 | 8.0 |
| | | Selenium (Se) | ND | 5.0 |
| | | Silver (Ag) | ND | 1.0 |
| | | Thallium (Tl) | ND | 5.0 |
| | | Vanadium (V) | 32 | 2.0 |
| | | Zinc (Zn) | 66 | 5.0 |

| | | | | |
|----------------|----------|----------------|-----------|-------------------|
| Date Sampled: | 07/12/17 | Date Analyzed: | 07/25/17 | QC Batch: B016894 |
| Date Received: | 07/14/17 | Method: | EPA 6010B | |



Mercury

| Lab# | Sample ID | Compound Name | Result (mg/kg) | RDL (mg/kg) |
|------------|--|---------------|----------------|-------------|
| 7071401-01 | B1 3.5', 5.5', 10.5' & 15.5' B2 3.5', 6', 11.5' & 15.5' | Mercury (Hg) | 0.12 | 0.10 |

| | | | | | |
|----------------|----------|----------------|-----------|-----------|---------|
| Date Sampled: | 07/12/17 | Date Analyzed: | 07/25/17 | QC Batch: | B016895 |
| Date Received: | 07/14/17 | Method: | EPA 7471A | | |

Resistivity

| Lab# | Sample ID | Compound Name | Result (ohms-cm) | RDL (ohms-cm) |
|------------|--|---------------|------------------|---------------|
| 7071401-01 | B1 3.5', 5.5', 10.5' & 15.5' B2 3.5', 6', 11.5' & 15.5' | Resistivity | 330 | 10 |

| | | | | | |
|----------------|----------|----------------|----------------|-----------|---------|
| Date Sampled: | 07/12/17 | Date Analyzed: | 07/18/17 | QC Batch: | B016885 |
| Date Received: | 07/14/17 | Method: | SM 2510 B-2011 | | |

Anions

| Lab# | Sample ID | Compound Name | Result (mg/kg) | RDL (mg/kg) |
|------------|--|----------------|----------------|-------------|
| 7071401-01 | B1 3.5', 5.5', 10.5' & 15.5' B2 3.5', 6', 11.5' & 15.5' | Chloride | 2200 | 200 |
| | | Sulfate as SO4 | 190 | 10 |

| | | | | | |
|----------------|----------|----------------|-----------|-----------|---------|
| Date Sampled: | 07/12/17 | Date Analyzed: | 07/25/17 | QC Batch: | B016905 |
| Date Received: | 07/14/17 | Method: | EPA 300.0 | | |



Notes and Definitions

| | |
|-----|--|
| RDL | Reporting Detection Limit |
| ND | Analyte NOT DETECTED at or above the reporting detection limit (RDL) |
| RPD | Relative Percent Difference |
| NR | Not Reported |



Analytical Sciences
P.O. Box 750336, Petaluma, CA 94975-0336
110 Liberty Street, Petaluma, CA 94952
(707) 769-3128

CHAIN OF CUSTODY

7071401

Eric Dabarian

LAB PROJECT NUMBER:

PROJECT NAME: Carollo - Coloma Pump Station

2213-004

GEOTRACKER EDF: __ Y __ N

GLOBAL ID: _____

COOLER TEMPERATURE

° C

COC

PAGE __ OF __

BILLING INFORMATION

CONTACT: **Laura**
COMPANY NAME: **Miller Pacific Engineering**
ADDRESS: **504 Redwood Blvd., Ste. 200**
Novato, CA 94947
PHONE #: **415-382-3444**
FAX #: **415-382-3450**

CLIENT INFORMATION

COMPANY NAME: **Miller Pacific Engineering**
ADDRESS: **504 Redwood Blvd., Suite 200**
Novato, CA 94947
CONTACT: **415-382-3444** FAX: **415-382-3450**
PHONE #: **415-382-3444** FAX: **415-382-3450**
EMAIL: _____

TURNAROUND TIME (CHECK ONE)

MOBILE LAB _____
SAME DAY _____ 24 HOURS _____
48 HOURS _____ 72 HOURS _____
5 DAYS _____ NORMAL ☒

ANALYSIS

| ITEM | CLIENT SAMPLE I.D. | DATE SAMPLED | TIME | MATRIX | # CONT. | PRESV. YES/NO | volatile hydrocarbons | semi-volatile hydrocarbons | total petroleum hydrocarbons, diesel & oil | total petroleum hydrocarbons, gasoline | corrosivity suite, sulfate, chloride, ph, resistivity | COMMENTS | LAB SAMPLE # |
|------|--------------------|--------------|--------|--------|---------|---------------|-----------------------|----------------------------|--|--|---|--------------------------|--------------|
| 1 | B1 3.5' & 5.5' | 12-Jul | 10am | soil | 1 | no | X | X | X | X | X | composite all samples | 01 |
| 2 | B1 10.5' & 15.5' | 12-Jul | 11am | soil | 1 | no | X | X | X | X | X | ie only one set of tests | |
| 3 | B2 3.5' & 6' | 12-Jul | 12noon | soil | 1 | no | X | X | X | X | X | | |
| 4 | B2 11.5' | 12-Jul | 1pm | soil | 1 | no | X | X | X | X | X | | |
| 5 | B2 15.5' | 12-Jul | 2pm | soil | 1 | no | X | X | X | X | X | | |
| 6 | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | |

SIGNATURES

Sampled By: **Zoe Stephens**

7/14/17

8:00

RECEIVED BY LABORATORY:

7.14.17

8:00

Relinquished

Date

Time

SIGNATURE

DATE

TIME



McC Campbell Analytical, Inc.

"When Quality Counts"

1534 Willow Pass Road, Pittsburg, CA 94565-1701
Toll Free Telephone: (877) 252-9262 / Fax: (925) 252-9269
http://www.mcccampbell.com / E-mail: main@mcccampbell.com

Analytical Report

Client: Analytical Sciences
Date Received: 7/17/17 16:00
Date Prepared: 7/18/17
Project: 7071401; Carollo-Coloma Pump Station

WorkOrder: 1707577
Extraction Method: SW3550B
Analytical Method: SW8270C
Unit: mg/Kg

Semi-Volatile Organics

| Client ID | Lab ID | Matrix | Date Collected | Instrument | Batch ID |
|--|--------------|--------|------------------|------------------|----------|
| B1-3.5', 5.5', 10.5', 15.5', B2-3.5', 6', 11 | 1707577-001A | Soil | 07/12/2017 10:00 | GC21 | 142151 |
| Analytes | Result | RL | DF | Date Analyzed | |
| Acenaphthene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Acenaphthylene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Acetochlor | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Anthracene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Benidine | ND | 2.6 | 2 | 07/18/2017 16:30 | |
| Benzo (a) anthracene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Benzo (a) pyrene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Benzo (b) fluoranthene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Benzo (g,h,i) perylene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Benzo (k) fluoranthene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Benzyl Alcohol | ND | 2.6 | 2 | 07/18/2017 16:30 | |
| 1,1-Biphenyl | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Bis (2-chloroethoxy) Methane | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Bis (2-chloroethyl) Ether | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Bis (2-chloroisopropyl) Ether | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Bis (2-ethylhexyl) Adipate | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Bis (2-ethylhexyl) Phthalate | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| 4-Bromophenyl Phenyl Ether | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Butylbenzyl Phthalate | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| 4-Chloroaniline | ND | 1.0 | 2 | 07/18/2017 16:30 | |
| 4-Chloro-3-methylphenol | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| 2-Chloronaphthalene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| 2-Chlorophenol | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| 4-Chlorophenyl Phenyl Ether | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Chrysene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Dibenzo (a,h) anthracene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Dibenzofuran | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Di-n-butyl Phthalate | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| 1,2-Dichlorobenzene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| 1,3-Dichlorobenzene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| 1,4-Dichlorobenzene | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| 3,3-Dichlorobenzidine | ND | 1.0 | 2 | 07/18/2017 16:30 | |
| 2,4-Dichlorophenol | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Diethyl Phthalate | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| 2,4-Dimethylphenol | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| Dimethyl Phthalate | ND | 0.50 | 2 | 07/18/2017 16:30 | |
| 4,6-Dinitro-2-methylphenol | ND | 2.6 | 2 | 07/18/2017 16:30 | |

(Cont.)

NELAP 4033ORELAP

Angela Rydelius, Lab Manager



Analytical Report

Client: Analytical Sciences
Date Received: 7/17/17 16:00
Date Prepared: 7/18/17
Project: 7071401; Carollo-Coloma Pump Station

WorkOrder: 1707577
Extraction Method: SW3550B
Analytical Method: SW8270C
Unit: mg/Kg

Semi-Volatile Organics

| Client ID | Lab ID | Matrix | Date Collected | Instrument | Batch ID |
|--|---------------|--------|------------------|------------|----------------------|
| B1-3.5', 5.5', 10.5', 15.5', B2-3.5', 6', 11 | 1707577-001A | Soil | 07/12/2017 10:00 | GC21 | 142151 |
| <u>Analytes</u> | <u>Result</u> | | <u>RL</u> | <u>DF</u> | <u>Date Analyzed</u> |
| 2,4-Dinitrophenol | ND | | 13 | 2 | 07/18/2017 16:30 |
| 2,4-Dinitrotoluene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| 2,6-Dinitrotoluene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Di-n-octyl Phthalate | ND | | 1.0 | 2 | 07/18/2017 16:30 |
| 1,2-Diphenylhydrazine | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Fluoranthene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Fluorene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Hexachlorobenzene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Hexachlorobutadiene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Hexachlorocyclopentadiene | ND | | 2.6 | 2 | 07/18/2017 16:30 |
| Hexachloroethane | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Indeno (1,2,3-cd) pyrene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Isophorone | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| 2-Methylnaphthalene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| 2-Methylphenol (o-Cresol) | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| 3 & 4-Methylphenol (m,p-Cresol) | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Naphthalene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| 2-Nitroaniline | ND | | 2.6 | 2 | 07/18/2017 16:30 |
| 3-Nitroaniline | ND | | 2.6 | 2 | 07/18/2017 16:30 |
| 4-Nitroaniline | ND | | 2.6 | 2 | 07/18/2017 16:30 |
| Nitrobenzene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| 2-Nitrophenol | ND | | 2.6 | 2 | 07/18/2017 16:30 |
| 4-Nitrophenol | ND | | 2.6 | 2 | 07/18/2017 16:30 |
| N-Nitrosodiphenylamine | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| N-Nitrosodi-n-propylamine | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Pentachlorophenol | ND | | 2.6 | 2 | 07/18/2017 16:30 |
| Phenanthrene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Phenol | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Pyrene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| Pyridine | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| 1,2,4-Trichlorobenzene | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| 2,4,5-Trichlorophenol | ND | | 0.50 | 2 | 07/18/2017 16:30 |
| 2,4,6-Trichlorophenol | ND | | 0.50 | 2 | 07/18/2017 16:30 |

(Cont.)

NELAP 4033ORELAP

Angela Rydelius, Lab Manager



McC Campbell Analytical, Inc.
"When Quality Counts"

1534 Willow Pass Road, Pittsburg, CA 94565-1701
Toll Free Telephone: (877) 252-9262 / Fax: (925) 252-9269
http://www.mcccampbell.com / E-mail: main@mcccampbell.com

Analytical Report

Client: Analytical Sciences
Date Received: 7/17/17 16:00
Date Prepared: 7/18/17
Project: 7071401; Carollo-Coloma Pump Station

WorkOrder: 1707577
Extraction Method: SW3550B
Analytical Method: SW8270C
Unit: mg/Kg

Semi-Volatile Organics

| Client ID | Lab ID | Matrix | Date Collected | Instrument | Batch ID |
|--|--------------|--------|------------------|------------|----------|
| B1-3.5', 5.5', 10.5', 15.5', B2-3.5', 6', 11 | 1707577-001A | Soil | 07/12/2017 10:00 | GC21 | 142151 |

| Analytes | Result | RL | DF | Date Analyzed |
|----------------------|----------------|---------------|----|------------------|
| <u>Surrogates</u> | <u>REC (%)</u> | <u>Limits</u> | | |
| 2-Fluorophenol | 73 | 30-130 | | 07/18/2017 16:30 |
| Phenol-d5 | 69 | 30-130 | | 07/18/2017 16:30 |
| Nitrobenzene-d5 | 78 | 30-130 | | 07/18/2017 16:30 |
| 2-Fluorobiphenyl | 75 | 30-130 | | 07/18/2017 16:30 |
| 2,4,6-Tribromophenol | 42 | 16-130 | | 07/18/2017 16:30 |
| 4-Terphenyl-d14 | 82 | 30-130 | | 07/18/2017 16:30 |

Analyst(s): REB

Analytical Comments: a3



Glossary of Terms & Qualifier Definitions

Client: Analytical Sciences
Project: 7071401; Carollo-Coloma Pump Station
WorkOrder: 1707577

Quality Control Qualifiers

F2 LCS/LCSD recovery and/or RPD is out of acceptance criteria.



Glossary of Terms & Qualifier Definitions

Client: Analytical Sciences
Project: 7071401; Carollo-Coloma Pump Station
WorkOrder: 1707577

Glossary Abbreviation

| | |
|--------------|--|
| %D | Serial Dilution Percent Difference |
| 95% Interval | 95% Confident Interval |
| DF | Dilution Factor |
| DI WET | (DISTLC) Waste Extraction Test using DI water |
| DISS | Dissolved (direct analysis of 0.45 µm filtered and acidified water sample) |
| DLT | Dilution Test (Serial Dilution) |
| DUP | Duplicate |
| EDL | Estimated Detection Limit |
| ERS | External reference sample. Second source calibration verification. |
| ITEF | International Toxicity Equivalence Factor |
| LCS | Laboratory Control Sample |
| MB | Method Blank |
| MB % Rec | % Recovery of Surrogate in Method Blank, if applicable |
| MDL | Method Detection Limit |
| ML | Minimum Level of Quantitation |
| MS | Matrix Spike |
| MSD | Matrix Spike Duplicate |
| N/A | Not Applicable |
| ND | Not detected at or above the indicated MDL or RL |
| NR | Data Not Reported due to matrix interference or insufficient sample amount. |
| PDS | Post Digestion Spike |
| PDSD | Post Digestion Spike Duplicate |
| PF | Prep Factor |
| RD | Relative Difference |
| RL | Reporting Limit (The RL is the lowest calibration standard in a multipoint calibration.) |
| RPD | Relative Percent Deviation |
| RRT | Relative Retention Time |
| SPK Val | Spike Value |
| SPKRef Val | Spike Reference Value |
| SPLP | Synthetic Precipitation Leachate Procedure |
| ST | Sorbent Tube |
| TCLP | Toxicity Characteristic Leachate Procedure |
| TEQ | Toxicity Equivalents |
| WET (STLC) | Waste Extraction Test (Soluble Threshold Limit Concentration) |

Analytical Qualifiers

a3 Sample diluted due to high organic content.



Analytical Sciences
P.O. Box 750336, Petaluma, CA 94975-0336
110 Liberty Street, Petaluma, CA 94952
(707) 769-3128
Fax (707) 769-8093

CHAIN OF CUSTODY

1707577

SUBCONTRACT LAB: McC Campbell Analytical
AS Project Name: Carroll - Coloma Pump Station
AS Project Number: 7071401

| CLIENT INFORMATION | |
|------------------------------|-------------------------|
| Company Name: | ANALYTICAL SCIENCES |
| Address: | P.O. BOX 750336 |
| | PETALUMA, CA 94975-0336 |
| Contact: | Michele Peters |
| Phone #: | 707-769-3128 |
| Fax #: | 707-769-8093 |
| email: analytical110@aol.com | |

| | |
|-------------------|-------------------------------------|
| EDT Required: YES | <input checked="" type="radio"/> NO |
| System ID: | |

| TURNAROUND TIME (check one) | |
|-----------------------------|--|
| Same Day | 72 Hours |
| 48 Hours | 24 Hours |
| 5 Days | Normal <input checked="" type="checkbox"/> |

Page 1 of 1

| Item | Client Sample ID | Date Sampled | Time | Matrix | # Cont. | Presv. Y/N | ANALYSIS | | | | | | | | | | | Comments | Lab Sample # | |
|------|---|--------------|------|--------|---------|------------|------------|------------|------|------|------|---------|-----|-----|------|------|--|----------|--------------|-----|
| | | | | | | | EDB by 504 | HAA by 552 | 8270 | 8081 | 8082 | Cyanide | 624 | 625 | 8141 | 8151 | | | | |
| 1 | 81-35.5, 5.5, 10.5, 15.5 82-35.6, 11.5, 15.5 | 7/12/17 | 1000 | Soil | 1 | N | | | X | | | | | | | | | | 7071401 | -01 |
| 2 | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | Normal TAT | |

| SIGNATURES | | | |
|------------------|--------------------|---------------|-------------|
| Relinquished By: | <u>[Signature]</u> | <u>7/17</u> | <u>850</u> |
| Signature | | Date | Time |
| Received By: | <u>[Signature]</u> | <u>7-2-17</u> | <u>0800</u> |
| Signature | | Date | Time |

[Signature] 7-12-17 1600


[Signature] 7/17/17 1600

412°




APPENDIX C

RESULTS OF LATERAL PILE ANALYSIS



EQUIPMENT PAD PLAN
(NO SCALE)



EQUIPMENT PAD SECTION
(NO SCALE)



**MILLER PACIFIC
ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2019, ALL RIGHTS RESERVED
FILE: 2213.004 Pier Layout.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

PIER LAYOUT & LOADING - EAST-WEST DIRECTION


SMCSD Coloma Pump Station
Sausalito, California


Project No. 2213.004


Date: 7/8/2019


Drawn RCA
Checked

C-1
FIGURE










EQUIPMENT PAD PLAN
(NO SCALE)



EQUIPMENT PAD SECTION
(NO SCALE)



MILLER PACIFIC
ENGINEERING GROUP

A CALIFORNIA CORPORATION, © 2019, ALL RIGHTS RESERVED
FILE: 2213.004 Pier Layout.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

PIER LAYOUT & LOADING - NORTH-SOUTH DIRECTION


SMCSD Coloma Pump Station
Sausalito, California

Project No. 2213.004


Date: 7/8/2019

Drawn RCA
Checked


C-2
FIGURE



24 in, N-S, P 195 kips, V = 51 kips



24 in, N-S, P = 195 kips, V = 151 kips





July 7, 2020
File: 2213.004altr.doc

Carollo Engineers, Inc.
2700 Ygnacio Valley Road, Suite 300
Walnut Creek, California 94598

Attn: James Wickstrom

Re: Addendum No. 1
2019 CBC Seismic Design Criteria
SMCSD Coloma Pump Station
Sausalito, California

This Addendum No. 1 to our Geotechnical Investigation Report dated July 5, 2019¹ provides updated seismic design criteria for the Sausalito Marin City Sanitary District's Coloma Pump Station planned near the intersection of Coloma Street and Bridgeway in Sausalito. The site is located close to several active faults, including the San Andreas and San Gregorio Faults which are located approximately 10.1 kilometers (6.3 miles) and 13.6 kilometers (8.5 miles) southwest of the site, respectively. The seismic design criteria provided in our report was based upon the 2016 California Building Code (CBC) and ASCE 7-10 which were the governing codes at the time our report was issued. We understand the new structures will be designed using the 2019 CBC and ASCE 7-16. Therefore, updated criteria based on the current codes are presented herein.

The site is underlain by roughly ten feet of artificial fill over Bay Mud. Moderately to highly weathered sandstone was encountered beneath the Bay Mud at about 20 feet below ground surface. Based on these subsurface conditions and the proximity to several active faults, the site is classified as "Site Class E". We performed a site-specific ground motion hazard analysis in general accordance with Section 21.2 of ASCE 7-16. The results of our analysis are presented on Figures 1 to 3 and the recommended seismic design criteria is summarized in Table 1.

¹ Miller Pacific Engineering Group, "Geotechnical Investigation, Sausalito Marin City Sanitary District, Coloma Pump Station, Sausalito, California", July 5, 2019.

Table 1 – 2019 California Building Code Seismic Design Criteria

| Parameter | Design Value |
|---|--------------|
| Site Class | E |
| Risk Category | III |
| Site Latitude | 37.868°N |
| Site Longitude | -122.503°W |
| Spectral Acceleration at Short Periods, S_s | 1.50 g |
| Spectral Acceleration at Period of 1 sec, S_1 | 0.60 g |
| Adjusted Spectral Acceleration at Short Periods, S_{MS} | 1.56 g |
| Adjusted Spectral Acceleration at Period of 1 sec, S_{M1} | 3.39 g |
| Design Spectral Acceleration at Short Periods, S_{DS} | 1.04 g |
| Design Spectral Acceleration at Period of 1 sec, S_{D1} | 2.26 g |
| Adjusted MCE_G Peak Ground Acceleration, PGA_M | 0.67 g |

We appreciate the opportunity to be of continued service on this project. If we can be of further assistance or should there be any questions or concerns regarding our recommendations, please call.

Very truly yours,
MILLER PACIFIC ENGINEERING GROUP

REVIEWED BY:



Rusty Arend
Geotechnical Engineer No. 3031
(Expires 6/30/21)



Benjamin Pappas
Geotechnical Engineer No. 2786
(Expires 9/30/20)

**ASCE 7-16
SITE SPECIFIC RISK-TARGETED
MAXIMUM CONSIDERED EARTHQUAKE (MCE_R)**

Project Name: **SMCSD - Coloma Pump Station**
Project Numbr: **2213.004**

Latitude: **37.8680**
Longitude: **-122.9030**

General Seismic Parameters
ASCE 7-16 Section 11.4

Site Class: **E**
S_s (g): **1.50**
S₁ (g): **0.60**
F_a: **N/A**
F_v: **N/A**
T_L (sec): **12.0**
C_{RS}: **0.92**
C_{R1}: **0.90**

Minimum Design Spectra Parameters
ASCE 7-16 Section 21.3

Site Class: **E**
S_s (g): **1.50**
S₁ (g): **0.60**
F_a: **1.00**
F_v: **4.00**
S_{MS} (g): **1.50**
S_{M1} (g): **2.40**
S_{DS} (g): **1.00**
S_{D1} (g): **1.60**
T₀ (sec): **0.32**
T_S (sec): **1.60**

Deterministic MCE Screening
ASCE 7-16 (Sup #1) 21.2.3

F_a: **1.00**
1.2 x F_a (g): **1.20**
Max PSHA (g): **2.14**
DSHA Rqd.: **YES**

Min. Deterministic MCE
ASCE 7-16 (Sup #1) 21.2.2

F_a: **1.00**
1.5 x F_a (g): **1.50**
Max DSHA (g): **1.72**
Min MCE Rqd.: **NO**

Probabilistic MCE
ASCE 7-16 Section 21.2.1 - Method 1

| Period (sec) | Sa _{RSdD50} (g) | Sa _{RSdD50} (g) | Sa _{RSdD100} (g) | C _R | Sa (g) |
|--------------|--------------------------|--------------------------|---------------------------|----------------|--------|
| 0.01 | 0.73 | 1.10 | 0.80 | 0.916 | 0.74 |
| 0.10 | 1.15 | 1.10 | 1.27 | 0.916 | 1.16 |
| 0.20 | 1.53 | 1.10 | 1.68 | 0.916 | 1.54 |
| 0.30 | 1.81 | 1.13 | 2.04 | 0.914 | 1.86 |
| 0.50 | 2.01 | 1.18 | 2.36 | 0.910 | 2.14 |
| 0.75 | 1.80 | 1.24 | 2.23 | 0.905 | 2.02 |
| 1.00 | 1.67 | 1.30 | 2.17 | 0.900 | 1.95 |
| 2.00 | 1.24 | 1.35 | 1.67 | 0.900 | 1.50 |
| 3.00 | 0.90 | 1.40 | 1.26 | 0.900 | 1.13 |
| 4.00 | 0.66 | 1.45 | 0.96 | 0.900 | 0.86 |
| 5.00 | 0.50 | 1.50 | 0.75 | 0.900 | 0.68 |

Deterministic MCE
NGA West2 2014 - 84th Percentile

| Period (sec) | Sa _{RSdD50} (g) | Sa _{RSdD50} (g) | Sa _{RSdD100} (g) |
|--------------|--------------------------|--------------------------|---------------------------|
| 0.01 | 0.56 | 1.10 | 0.61 |
| 0.02 | 0.54 | 1.10 | 0.59 |
| 0.03 | 0.54 | 1.10 | 0.59 |
| 0.05 | 0.54 | 1.10 | 0.60 |
| 0.08 | 0.62 | 1.10 | 0.69 |
| 0.10 | 0.72 | 1.10 | 0.79 |
| 0.15 | 0.87 | 1.10 | 0.96 |
| 0.20 | 1.00 | 1.10 | 1.10 |
| 0.25 | 1.12 | 1.11 | 1.25 |
| 0.30 | 1.25 | 1.13 | 1.41 |
| 0.40 | 1.40 | 1.15 | 1.61 |
| 0.50 | 1.46 | 1.18 | 1.72 |
| 0.75 | 1.37 | 1.24 | 1.69 |
| 1.00 | 1.32 | 1.30 | 1.72 |
| 1.50 | 1.20 | 1.33 | 1.59 |
| 2.00 | 1.07 | 1.35 | 1.44 |
| 3.00 | 0.79 | 1.40 | 1.11 |
| 4.00 | 0.58 | 1.45 | 0.85 |
| 5.00 | 0.44 | 1.50 | 0.66 |
| 7.50 | 0.22 | 1.50 | 0.33 |
| 10.00 | 0.12 | 1.50 | 0.18 |

Scaled Deterministic MCE
ASCE 7-16 (Sup #1) 21.2.2

| Period (sec) | Sa (g) |
|--------------|--------|
| 0.01 | 0.53 |
| 0.02 | 0.51 |
| 0.03 | 0.52 |
| 0.05 | 0.52 |
| 0.08 | 0.60 |
| 0.10 | 0.69 |
| 0.15 | 0.83 |
| 0.20 | 0.96 |
| 0.25 | 1.09 |
| 0.30 | 1.23 |
| 0.40 | 1.41 |
| 0.50 | 1.50 |
| 0.75 | 1.48 |
| 1.00 | 1.50 |
| 1.50 | 1.39 |
| 2.00 | 1.26 |
| 3.00 | 0.97 |
| 4.00 | 0.74 |
| 5.00 | 0.57 |
| 7.50 | 0.29 |
| 10.00 | 0.16 |

Site Specific MCE_s
ASCE 7-16 Section 21.2.3

| Period (sec) | Sa (g) |
|--------------|--------|
| 0.01 | 0.61 |
| 0.02 | 0.59 |
| 0.03 | 0.59 |
| 0.05 | 0.60 |
| 0.08 | 0.69 |
| 0.10 | 0.79 |
| 0.15 | 0.96 |
| 0.20 | 1.10 |
| 0.25 | 1.25 |
| 0.30 | 1.41 |
| 0.40 | 1.61 |
| 0.50 | 1.72 |
| 0.75 | 1.69 |
| 1.00 | 1.72 |
| 1.50 | 1.59 |
| 2.00 | 1.44 |
| 3.00 | 1.11 |
| 4.00 | 0.85 |
| 5.00 | 0.66 |
| 7.50 | 0.33 |
| 10.00 | 0.18 |

Site-Specific Design Spectrum
ASCE 7-16 Section 21.3

| Period (sec) | Sa (g) |
|--------------|--------|
| 0.01 | 0.41 |
| 0.02 | 0.39 |
| 0.03 | 0.39 |
| 0.05 | 0.40 |
| 0.08 | 0.46 |
| 0.10 | 0.53 |
| 0.15 | 0.64 |
| 0.20 | 0.73 |
| 0.25 | 0.83 |
| 0.30 | 0.94 |
| 0.40 | 1.08 |
| 0.50 | 1.15 |
| 0.75 | 1.13 |
| 1.00 | 1.14 |
| 1.50 | 1.06 |
| 2.00 | 0.96 |
| 3.00 | 0.74 |
| 4.00 | 0.56 |
| 5.00 | 0.44 |
| 7.50 | 0.22 |
| 10.00 | 0.12 |

80% General Response Spectrum
ASCE 7-16 Section 21.3

| Period (sec) | Sa (g) | 80% Sa (g) |
|--------------|--------|------------|
| 0.01 | 0.42 | 0.34 |
| 0.06 | 0.52 | 0.41 |
| 0.11 | 0.61 | 0.49 |
| 0.17 | 0.71 | 0.57 |
| 0.22 | 0.81 | 0.65 |
| 0.27 | 0.90 | 0.72 |
| 0.32 | 1.00 | 0.80 |
| 0.38 | 1.00 | 0.80 |
| 0.46 | 0.86 | 0.69 |
| 0.55 | 0.75 | 0.60 |
| 0.65 | 0.67 | 0.54 |
| 0.75 | 0.60 | 0.48 |
| 0.90 | 0.55 | 0.44 |
| 1.10 | 0.50 | 0.40 |
| 1.35 | 0.47 | 0.37 |
| 1.65 | 0.43 | 0.35 |
| 2.00 | 0.40 | 0.32 |
| 2.40 | 0.38 | 0.30 |
| 2.85 | 0.36 | 0.29 |
| 3.40 | 0.34 | 0.27 |
| 4.00 | 0.32 | 0.26 |

T₀ = 0.32
T_S = 1.60



A CALIFORNIA CORPORATION, © 2020, ALL RIGHTS RESERVED
FILE: 2213.004 2019 CBC Seismic Design Parameters.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

ASCE 7-16 MCE_r CALCULATIONS


SMCSD Coloma Pump Station
Sausalito, California

Project No. 2213.004 Date: 7/1/2020

Drawn RCA
Checked

1
FIGURE

SITE SPECIFIC SPECTRA CANDIDATES



MILLER PACIFIC
ENGINEERING GROUP

A CALIFORNIA CORPORATION, © 2020, ALL RIGHTS RESERVED
FILE: 2213.004 2019 CBC Seismic Design Parameters.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

ASCE 7-16 MCEr CANDIDATE SPECTRA

SMCSD Coloma Pump Station
Sausalito, California


Project No. 2213.004

Date: 7/1/2020

Drawn RCA
Checked

2
FIGURE

SITE SPECIFIC MCE_R



A CALIFORNIA CORPORATION, © 2020, ALL RIGHTS RESERVED
 FILE: 2213.004 2019 CBC Seismic Design Parameters.dwg

504 Redwood Blvd.
 Suite 220
 Novato, CA 94947
 T 415 / 382-3444
 F 415 / 382-3450
 www.millerpac.com

ASCE 7-16 MCEr DESIGN SPECTRUM

SMCSD Coloma Pump Station
 Sausalito, California

Project No. 2213.004

Date: 7/1/2020

Drawn RCA
 Checked

3
 FIGURE