

SAUSALITO-MARIN CITY SANITARY DISTRICT
COLOMA PUMP STATION REPLACEMENT PROJECT

Addendum No. 3

The following modifications to the scope of work for the Coloma Pump Station Replacement Project shall modify the Contract Documents as described. Work included in this Addendum shall be incorporated into and accomplished in accordance with all project requirements. This addendum contains 2 pages with no attachments.

IMPORTANT: Receipt of this Addendum must be acknowledged in the space provided on the Bid Form when your bid is submitted. Failure to acknowledge receipt of this addendum may constitute grounds for rejection of the bid.

Addendum Item:

3.1 Section 02552, Temporary Bypass Pumping:

1. Under paragraph 1.01.B, replace the entire paragraph with the following:

“Description: Bypass pumping shall consist of furnishing, installing, and maintaining all power, primary and standby pumps, bypass piping, spill guards, and appurtenances as required to maintain existing flows and services. Bypass pumping operations shall be monitored on-site or remotely by a competent person at all times (24 hours a day, 7 days per week) during its operation. Remote monitoring requires the capability to respond to alarms on-site within 30 minutes. All remote monitoring shall require the installation of an auto-dialer capable of calling multiple numbers until alarms are acknowledged. Remove bypass pumping facilities upon successful completion of the intended use.”

2. Under paragraph 1.02.A.6: Note that temporary power has already been applied for by the District in advance of awarding the construction contract as outlined in Addendum 1. All other requirements for temporary power remain.
3. Under paragraph 1.04.B.9.a, replace the entire paragraph with the following:

“Provide continuous (24 hours per day, 7 days per week) on-site or remote monitoring by a competent person during entire bypass period. Remote monitoring requires the capability to respond to alarms on-site within 30 minutes.”

4. Under paragraph 1.04.B.9.b: Revise "... 6 times a day." to "... 3 times a day during work hours permitted by the City of Sausalito's encroachment permit."
5. Under paragraph 1.04.C.9.a, replace the entire paragraph with the following:

“Provide continuous (24 hours per day, 7 days per week) on-site or remote monitoring by a competent person during entire bypass period. Remote monitoring requires the capability to respond to alarms on-site within 30 minutes.”
6. Under paragraph 1.04.C.9.b: Revise "... 6 times a day." to "... 3 times a day during work hours permitted by the City of Sausalito's encroachment permit."
7. Under paragraph 1.04.D.9.a, replace the entire paragraph with the following:

“Provide continuous (24 hours per day, 7 days per week) on-site or remote monitoring by a competent person during all periods that require dry weather operations (including winter months with light or no rain). Remote monitoring requires the capability to respond to alarms on-site within 30 minutes. For large storm events where District flows significantly increase, the Scotties pumps shall be continuously monitored on-site. Large events may occur several times during the winter but typically only last for several hours to 2 days. Contractor shall cover all costs associated with 6 large storm events lasting 48 hours each.”
8. Under paragraph 1.04.D.9.b: Revise "... 6 times a day." to "... 3 times a day during work hours permitted by the City of Sausalito's encroachment permit."

This Addendum No. 3 shall become part of the Contract and all provisions of the Contract shall apply thereto.