

**SAUSALITO-MARIN CITY SANITARY DISTRICT**  
**SCREW PRESS RELOCATION PROJECT**

**Addendum No. 2**

The following shall modify the Contract Documents. The work shall be accomplished in accordance with such modifications. It is required that this addendum be attached to the Specifications.

**IMPORTANT: Receipt of this Addendum must be acknowledged in the space provided on the Bid form when your bid is submitted. Failure to acknowledge receipt of this addendum may constitute grounds for rejection of the bid.**

**Addendum Items:**

**Item 2.1:** Bidder Questions: The following questions were raised at the project's pre-bid meeting held on October 3, 2024:

- a) Q: Can the return box be shut down to install the drain line?  
A: The return box will continue to receive flow but can be cored above the water level. All debris must be captured.
- b) Q: How can the return box be accessed from the bottom (e.g. scaffold, manlift)?  
A: It is the Contractor's responsibility to determine access and safety requirements. Scaffolding may be placed on the walkway below the return box. This is not a primary pathway and can be blocked.
- c) Q: Various questions related to the existing FKC screw press.  
A: See project specifications including Appendix A.
- d) Q: Are sludge disposal requirements in the specs and addendum?  
A: Yes, see Bid Item 7 and Addenda Item 1.4.
- e) Q: Does the project have any MBE or DBE requirements?  
A: No.
- f) Q: Is there a soils report?  
A: The District has Geotech reports from previous projects which can be provided upon request. However, soil reports should not be required for the

limited quantity of work required; pipe supports only. Contractor shall provide supports as detailed on Drawing M-22.

g) Q: Is there any excavation needed?

A: Excavation is limited to pipe supports as shown on Drawing M-22.

h) Q: What is the anticipated start date?

A: Assuming the District's Board of Directors awards the project to a responsive and responsible bidder at their November 5, 2024 meeting, a notice of award will be issued within one week. The project's notice to proceed is typically issued within 30 days of award.

**Item 2.2:** Correction to Bidder Qualifications; See Section 400, Attachment A: The project manager's experience must have been achieved **within the past eight (8) years**.

**Item 2.3:** Correction to Bidder Qualifications; See Section 400, Attachment B: **The certification of electrical subcontractor's experience and qualifications are to be submitted within 3 days of the project bid.** If the prime contractor elects to self-perform the electrical scope of work they shall provide this information on their own behalf to ensure they meet the minimum standards of experience and qualifications necessary to perform the work.

**This Addendum No. 2 shall become part of the Contract and all provisions of the Contract shall apply thereto.**